

Q ( 名乗らず ) 飛散対策について、散布するのは樹脂というべきか塗料と  
いうべきか。

A : 主成分は、合成樹脂エマルジョンということ。

Q : 土壌対策とっていいのか。

A : 土壌の粉じん飛散対策。

Q : 建屋にはかけないのか。

A : 実験してみたとなつてまずいところにはかけないということ。

Q : 水質南放水口と北放水口の測定点の距離教えてほしい。

A : 北放水口と南放水口 1. 1 km 南放水高から測定点まで 330 m、北放  
水口から測定点まで 50 m。単純に合わせると約 1. 5 km。

Q : 昨日から非常用ディーゼルに切り替わった。メリット消防ポンプより給油  
の機会が少なくてよいということでしょうか。

A : 現場の感触ではスムーズに水が入るようになったということ。燃料の問題  
もあるが流れがよくなる。

Q : 出力自体はそんなに変わらないのか。

A : 出力が違う可能性もあるのでよくわからない。

以上

スクリーニングの状況

宮城 ← ERC医療 3/30

原子力安全・保安院

情報入手日時	検査人数	線量等	人数内訳	処置不要人数	除染処置人数	病院搬送人数	病院名	備考(属性等)
3月16日 11:00時点 での累計	162	6,000cpm未満	110	112	39	0		住民(28) 警察(2) 原発関係者(64) その他の民間企業(54) 自衛隊(3)
		6,000cpm以上	41					
		13,000cpm未満	8					
		13,000cpm以上 100,000cpm未満	2					
		100,000cpm以上	1				太田西ノ内病院 (3) 県立医大(1) 放医研(1)	原発関係者(4) 自衛隊(4) その他の民間企業 (3)
3月16日	集計中							県において、被ばく者 情報の取りまとめが遅 れている。
3月17日	集計中							
3月17日 20:00時点 での追加	19548	100,000cpm未満	18629	不明	不明	不明	不明	福島県で集計中の情報 (未公開情報)検査人数と 線量等の人数内訳が合 わないのは、一部線量等 の情報が無いため。
		100,000cpm以上	60					
3月18日	集計中							本が行われる県の対策 会議に向けて保健所等 に問い合わせて集計作業 中。その後は1日1回 の更新ができる予定。

経済産業省  
番号 302016

1/7  
研 7/18 ← 9/17

情報入手日時	検査人数	線量等		人数内訳	処置不要人数	除染処置人数	病院搬送人数	病院名	備考 (属性等)
		13,000cpm未満	13,000cpm以上 100,000cpm未満						
3月18日 20:00時点 での追加	42440	13,000cpm未満		30143	-	-	-	-	3月17日 20:00時点の実績が精査され、さらに追加もされたため、当該実績を基本にし、追加していくこととする。プリアス未発表とのこと。取扱注意でお願いいたします。人数の計が含まれないのは実績が不明の箇所があるため。 100,000cpm以上が検出された者は、除染後の再検査では異常は見られなかった。
		13,000cpm以上 100,000cpm未満		1409					
		100,000cpm以上		56					
3月19日 8:00時点 での追加	集計中								福島県が1日1回程度の更新となるため追加情報なし。(県は現時点で未公表)
3月19日 20:00時点 での追加	集計中								福島県が1日1回程度の更新となるため追加情報なし。(県は現時点で未公表)
3月20日 8:00時点 での追加	56776	13,000cpm未満		33370	-	-	-	-	3月18日 20:00時点の実績が精査され、さらに追加もされた。一部修正があつたため、当該実績を基本とする。プリアス未発表とのこと。取扱注意でお願いいたします。人数の計が含まれないのは実績が不明の箇所があるため。 100,000cpm以上が検出された者は、除染後の再検査では異常は見られなかった。
		13,000cpm以上 100,000cpm未満		535					
		100,000cpm以上		95					
3月20日 20:00時点	集計中								福島県が1日1回程度の更新となるため追加

情報入手日時	検査人数	線量等	人数内訳	処置不要人数	除染処置人数	病院搬送人数	病院名	備考（属性等）
3月21日 8:00時点 での追加	10058	13,000cpm未満 13,000cpm以上 100,000cpm未満 100,000cpm以上	9994	-	-	-	-	3/20 8:00時点からの追加情報、引き続き未公表情報となつているため、取扱注意。
			63					
			1					
3月21日 20:00時点 での追加	5818	13,000cpm未満 13,000cpm以上 100,000cpm未満 100,000cpm以上	5775	-	-	-	-	3/21 8:00時点からの追加情報、引き続き未公表情報となつているため、取扱注意。
			43					
			0					
3月22日 8:00時点 での追加	集計中							

情報入手日時	検査人数	線量等	人数内訳	処置不要人数	除染処置人数	病院搬送人数		病院名	備考 (属性等)
						院内	院外		
3月22日 20:00時点 での追加	2777	13,000cpm未満	2743	-	-	-	-	-	3/21 20:00時点からの追加情報。引き続き未公表情報となっているため、取扱注意。
		13,000cpm以上 100,000cpm未満	33						
		100,000cpm以上	1						
3月23日 8:00時点 での追加	集計中	13,000cpm未満	4449	-	-	-	-	-	3/22 20:00時点からの追加情報。実施日毎のスクリーニング数等については公表したが、実態表については取扱注意。
		13,000cpm以上 100,000cpm未満	41						
		100,000cpm以上	1						
3月24日 8:00時点 での追加	集計中			-	-	-	-	-	
		13,000cpm未満	3985						
3月24日 20:00時点 での追加	4000	13,000cpm以上 100,000cpm未満	15	-	-	-	0	-	3/23 20:00時点からの追加情報。実施日毎のスクリーニング数等については公表したが、実態表に

情報入手日時	検査人数	検査等	人数内訳	処置不要人数	除染処置人数	病院搬送人数	病院名	備考 (属性等)		
3月25日 8:00時点 での追加	集計中	100,000cpm以上	0					ついては取扱注意。		
									13,000cpm未満	3874
									13,000cpm以上 100,000cpm未満	19
3月25日 20:00時点 での追加	3893	100,000cpm以上	0					3/24 20:00時点からの追加情報。実施日毎のスクリーニング数等については公表したが、実績表については取扱注意。		
3月26日 8:00時点 での追加	集計中									
3月26日 20:00時点 での追加	3955	100,000cpm以上	0					3/25 20:00時点からの追加情報。実施日毎のスクリーニング数等については公表したが、実績表については取扱注意。		
									13,000cpm未満	3947
									13,000cpm以上 100,000cpm未満	8
2日7日	8:00時点	検査中								

情報入手日時	検査人数	線量等	人数内訳	処置不要人数	除染処置人数	病院搬送人数	病院名	備考 (属性等)
3月27日 20:00時点 での追加	3605	13,000cpm未満 13,000cpm以上 100,000cpm未満 100,000cpm以上	3595 10 0	-	-	0		3/26 20:00時点からの追加情報。実施日毎のスクリーニング数等については公表したが、実績表については取扱注意。
3月28日 8:00時点 での追加	集計中							
3月28日 20:00時点 での追加	3571	13,000cpm未満 13,000cpm以上 100,000cpm未満 100,000cpm以上	3560 10 1	-	-	0		3/27 20:00時点からの追加情報。実施日毎のスクリーニング数等については公表したが、実績表については取扱注意。
3月29日 8:00時点 での追加	集計中							
3月29日 20:00時点 での追加	3398	13,000cpm未満 13,000cpm以上 100,000cpm未満	3387 9	-	-	0		3/28 20:00時点からの追加情報。実施日毎のスクリーニング数等については公表したが、実績表に

情報入手日時	検査人数	線量等	人数内訳	処置不要人数	除染処置人数	病院		備考 (属性等)
						搬送人数	名	
3月30日	8:00時点での追加	100,000cpm以上	2					ついでに取扱注意。
3月30日	20:00時点での追加	13,000cpm未満	3745					3/29 20:00時点からの追加情報。実施日毎のスクリーニング数等については公表したが、実績表については取扱注意。
		13,000cpm以上 100,000cpm未満	7					
		100,000cpm以上	1					

7/7

件名 Effect of the earthquake on the Nuclear Facilities in North-east area of Japan


▼ 操作を選択

送信者

宛先

Cc

送信日時 2011年03月11日(金) 17:15:12

添付ファイル  110311\_press\_release\_on\_earthquake1.pdf

Dear

Sorry for my frequent e-mail.

10 NPPs in Japan were automatically shut down in consequence of an earthquake occurring at 14:46 on 11th of March JST.

Attached is a prompt report from NISA sent diplomatically.

FYI.

Toshihiro

<input type="checkbox"/> 件名	Re: Effect of the earthquake on the Nuclear Facilities in North-east area of Japan	<input type="button" value="▼ 操作を選択"/>
送信者	[REDACTED]	
宛先	[REDACTED]	
Cc	[REDACTED]	
送信日時	2011年03月11日(金) 19:16:00	
添付ファイル	<input type="checkbox"/> News Releases No.2 IAEA.docx	
Dear [REDACTED]		
<p>Here attached is the 2nd press release on earthquake. At Fukushima Daiichi Nuc Power Station, I heard external power outage is taking place.</p>		
Toshihiro		
----- Original Message -----		
> Dear [REDACTED],		
>		
> Sorry for my frequent e-mail.		
> 10 NPPs in Japan were automatically shut down in consequence of an		
> earthquake occuring at 14:46 on 11th of March JST.		
> Attached is a prompt report from NISA sent diplomatically.		
> FYI.		
>		
> Toshihiro		
>		

---

From: [REDACTED]  
Sent: 2011年3月11日 金曜日 6:37  
To: [REDACTED]  
Subject: Re: Effect of the earthquake on the Nuclear Facilities in North-east area of Japan

Dear [REDACTED]

Thank you.

[REDACTED]  
Sent from Blackberry.

----- Original Message -----

From: [REDACTED]  
To: [REDACTED]  
Sent: Fri Mar 11 06:35:01 2011  
Subject: Re: Effect of the earthquake on the Nuclear Facilities in North-east area of Japan

Dear [REDACTED]

Please allow me to share the latest information with you.  
Toshihiro

----- Original Message -----

> Dear [REDACTED]  
>  
> This event is being largely carried by media now, so if any staff  
> members in NRC want to know about it, please forward my information.  
>  
> Toshihiro

> ----- Original Message -----

>> Dear Bannai-san,  
>>  
>> Thank you very much for this information. I know you are very  
> concerned about the situation. Please let me know if there is anything  
> the NRC can do to help.  
>>  
>> I appreciate any information you provide.  
>>  
>> Best Regards.

>> [REDACTED]  
>> Sent from Blackberry.

>> ----- Original Message -----

>> From: [REDACTED]  
>> To: [REDACTED]  
>> Cc: Hidehiko Yamachika [REDACTED]  
>> Sent: Fri Mar 11 03:15:12 2011  
>> Subject: Effect of the earthquake on the Nuclear Facilities in  
North-

> east area of Japan

>> Dear [REDACTED]

>> Sorry for my frequent e-mail.

>> 10 NPPs in Japan were automatically shut down in consequence of an  
>> earthquake occurring at 14:46 on 11th of March JST.  
>> Attached is a prompt report from NISA sent diplomatically.  
>> FYI.  
>>  
>> Toshihiro  
>>  
>  
>

---

From: [REDACTED]  
Sent: 2011年3月11日金曜日 5:10  
To: [REDACTED]  
Cc: [REDACTED]  
Subject: Re: Effect of the earthquake on the Nuclear Facilities in North-east area of Japan

Dear Bannai-san,

Thank you very much for this information. I know you are very concerned about the situation. Please let me know if there is anything the NRC can do to help.

I appreciate any information you provide.

Best Regards.

[REDACTED]  
Sent from Blackberry.

----- Original Message -----

From: [REDACTED]  
To: [REDACTED]  
Cc: Hidehiko Yamachika [REDACTED]  
Sent: Fri Mar 11 03:15:12 2011  
Subject: Effect of the earthquake on the Nuclear Facilities in North-east area of Japan

Dear [REDACTED]

Sorry for my frequent e-mail.

10 NPPs in Japan were automatically shut down in consequence of an earthquake occurring at 14:46 on 11th of March JST.

Attached is a prompt report from NISA sent diplomatically.

FYI.

Toshihiro

件名 Re: Effect of the earthquake on the Nuclear Facilities in North-east area of Japan

送信者

宛先

送信日時 2011年03月11日(金) 20:35:01

▼ 操作を選択

添付ファイル News Releases No4 IAEA.docx

Dear

Please allow me to share the latest information with you.  
Toshihiro

----- Original Message -----

> Dear

>

> This event is being largely carried by media now, so if any staff  
> members in NRC want to know about it, please forward my information.

> Toshihiro

>

> ----- Original Message -----

> > Dear Bannai-san,

> >

> > Thank you very much for this information. I know you are very  
> concerned about the situation. Please let me know if there is anything  
> the NRC can do to help.

> >

> > I appreciate any information you provide.

> >

> > Best Regards.

> >

> >

> > Sent from Blackberry.

> >

> > ----- Original Message -----

> > From:

> > To:

> > Cc: Hidehiko Yamachika

> > Sent: Fri Mar 11 03:15:12 2011

> > Subject: Effect of the earthquake on the Nuclear Facilities in

North-

> east area of Japan

> >

> > Dear

> >

> > Sorry for my frequent e-mail.

> > 10 NPPs in Japan were automatically shut down in consequence of an  
> > earthquake occurring at 14:46 on 11th of March JST.

> > Attached is a prompt report from NISA sent diplomatically.

> > FYI.

> >

> > Toshihiro

> >

>

>

件名 Re: Effect of the earthquake on the Nuclear Facilities in North-east area of Japan  
送信者 [REDACTED]  
宛先 [REDACTED]  
Cc [REDACTED]  
送信日時 2011年03月11日(金) 19:50:07

▼ 操作を選択

Dear [REDACTED]

This event is being largely carried by media now, so if any staff members in NRC want to know about it, please forward my information.

Toshihiro

----- Original Message -----

> Dear Bannai-san,  
>  
> Thank you very much for this information. I know you are very concerned about the situation. Please let me know if there is anything the NRC can do to help.  
>  
> I appreciate any information you provide.  
>  
> Best Regards.  
>  
> [REDACTED]  
> Sent from Blackberry.

> ----- Original Message -----

> From: [REDACTED]  
> To: [REDACTED]  
> Cc: Hidehiko Yamachika [REDACTED]  
> Sent: Fri Mar 11 03:15:12 2011  
> Subject: Effect of the earthquake on the Nuclear Facilities in North-east area of Japan

> Dear [REDACTED]

>  
> Sorry for my frequent e-mail.  
> 10 NPPs in Japan were automatically shut down in consequence of an earthquake occurring at 14:46 on 11th of March JST.  
> Attached is a prompt report from NISA sent diplomatically.  
> FYI.  
>  
> Toshihiro  
>