

2F-2号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa] (gage)	炉水位 [mm] 停止時	炉水温度[°C] 給水/スル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/3/26 0:00	0.02	6050	28.9	5.3	42.7	106	402	26
2011/3/26 1:00	0.02	6050	28.9	5.5	42.6	107	402	26
2011/3/26 2:00	0.02	6050	28.9	5.6	42.6	107	402	26
2011/3/26 3:00	0.03	6050	28.9	5.6	42.6	105	402	26
2011/3/26 4:00	0.03	6050	28.9	5.6	42.6	106	402	26
2011/3/26 5:00	0.02	6050	28.8	5.6	42.5	106	400	26
2011/3/26 6:00	0.03	6050	28.8	5.5	42.3	107	401	26
2011/3/26 7:00	0.03	6050	28.8	5.5	42.3	107	401	26
2011/3/26 8:00	0.02	6050	28.8	5.4	42.3	107	402	26
2011/3/26 9:00	0.02	6050	28.9	5.3	42.3	106	402	26
2011/3/26 10:00	0.03	6050	28.8	5.2	42.2	106	402	26
2011/3/26 11:00	0.03	6050	28.8	5.2	42.2	106	402	26
2011/3/26 12:00	0.03	6050	28.8	5.2	42.2	106	402	26
2011/3/26 13:00	0.03	6050	28.7	5.2	42.2	106	402	26
2011/3/26 14:00	0.03	6050	28.8	5.1	42.0	106	402	26
2011/3/26 15:00	0.03	6050	28.7	5.1	42.0	106	402	26
2011/3/26 16:00	0.03	6050	28.7	5.0	41.9	106	402	26
2011/3/26 17:00	0.02	6050	28.7	4.8	42.0	106	402	26
2011/3/26 18:00	0.02	6050	28.5	4.7	41.9	106	402	26
2011/3/26 19:00	0.02	6050	28.7	4.6	41.7	106	402	26
2011/3/26 20:00	0.03	6050	28.8	4.4	41.6	106	402	26
2011/3/26 21:00	0.03	6050	28.7	4.4	41.6	108	402	26
2011/3/26 22:00	0.02	6050	28.6	4.3	41.5	106	402	26
2011/3/26 23:00	0.03	6200	28.6	4.4	41.6	106	396	26
2011/3/27 0:00	0.03	6150	28.6	4.5	41.6	106	401	26
2011/3/27 1:00	0.03	6150	28.7	4.6	41.5	106	401	26
2011/3/27 2:00	0.02	6150	28.8	4.6	41.5	106	400	26
2011/3/27 3:00	0.03	6150	28.8	4.7	41.5	107	400	26
2011/3/27 4:00	0.03	6150	28.5	4.7	41.4	106	400	26
2011/3/27 5:00	0.03	6150	28.8	4.6	41.3	106	400	26
2011/3/27 6:00	0.03	6150	28.7	4.6	41.3	107	401	26
2011/3/27 7:00	0.03	6150	28.8	4.6	41.3	106	401	26
2011/3/27 8:00	0.03	6150	28.8	4.6	41.3	107	400	26
2011/3/27 9:00	0.03	6150	28.7	4.5	41.3	107	400	26
2011/3/27 10:00	0.03	6150	28.7	4.5	41.3	107	401	26
2011/3/27 12:00	0.02	6100	28.6	4.6	41.0	107	401	26
2011/3/27 14:00								
2011/3/27 16:00								
2011/3/27 18:00								
2011/3/27 20:00								
2011/3/27 22:00								
2011/3/28 0:00								

2F-3号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa (gage)]	炉水位 [mm] 777セット	炉水温度[°C] 給水ノズル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/3/26 0:00	0.01	4333	33.8	2	40.9	104	-19	26
2011/3/26 1:00	0.01	4337	33.8	2	40.6	104	-20	26
2011/3/26 2:00	0.01	4337	33.7	2	40.7	104	-20	26
2011/3/26 3:00	0.01	4337	33.7	3	40.6	104	-20	26
2011/3/26 4:00	0.01	4337	33.7	3	40.6	104	-20	26
2011/3/26 5:00	0.01	4337	33.7	3	40.6	104	-20	26
2011/3/26 6:00	0.01	4331	33.6	2	40.5	104	-19	26
2011/3/26 7:00	0.01	4330	33.6	2	40.5	104	-19	26
2011/3/26 8:00	0.01	4340	33.6	2	40.5	104	-19	26
2011/3/26 9:00	0.01	4344	33.5	2	40.5	104	-19	26
2011/3/26 10:00	0.01	4344	33.4	2	40.4	104	-20	26
2011/3/26 11:00	0.01	4344	33.4	2	40.4	104	-20	26
2011/3/26 12:00	0.01	4344	33.4	2	40.3	103	-20	26
2011/3/26 13:00	0.01	4347	33.4	2	40.4	103	-20	26
2011/3/26 14:00	0.01	4348	33.4	2	40.3	103	-20	26
2011/3/26 15:00	0.01	4348	33.4	2	40.2	103	-21	26
2011/3/26 16:00	0.01	4347	33.3	2	40.2	103	-20	26
2011/3/26 17:00	0.01	4350	33.3	2	40.1	103	-20	26
2011/3/26 18:00	0.01	4352	33.3	2	40.1	103	-20	26
2011/3/26 19:00	0.01	4352	33.3	2	40.1	103	-20	26
2011/3/26 20:00	0.01	4355	33.3	1	40.1	103	-20	26
2011/3/26 21:00	0.01	4355	33.2	1	40.0	103	-21	26
2011/3/26 22:00	0.01	4355	33.2	1	40.0	103	-20	26
2011/3/26 23:00	0.01	4358	33.2	1	40.0	103	-20	26
2011/3/27 0:00	0.01	4359	33.2	1	40.0	103	-20	26
2011/3/27 1:00	0.01	4361	33.2	1	39.9	103	-21	26
2011/3/27 2:00	0.01	4359	33.1	1	39.9	103	-21	26
2011/3/27 3:00	0.01	4362	33.1	1	39.9	103	-21	26
2011/3/27 4:00	0.01	4365	33.0	1	39.8	103	-21	26
2011/3/27 5:00	0.01	4361	33.0	1	39.7	103	-21	26
2011/3/27 6:00	0.01	4355	33.0	1	39.7	103	-21	26
2011/3/27 7:00	0.01	4354	32.9	1	39.7	103	-21	26
2011/3/27 8:00	0.01	4354	32.9	1	39.7	103	-21	26
2011/3/27 9:00	0.01	4357	32.9	1	39.8	103	-21	26
2011/3/27 10:00	0.01	4354	32.8	1	39.5	103	-21	26
2011/3/27 12:00	0.00	3642	36.0	1	39.5	104	17	26
2011/3/27 14:00								
2011/3/27 16:00								
2011/3/27 18:00								
2011/3/27 20:00								
2011/3/27 22:00								
2011/3/28 0:00								

炉水位、S/Cの水位の変動は、S/C運転モードを変更による。10:50 RHR(B)停止。

2F-4号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa (gage)]	炉水位 [mm] アブセト	炉水温度[°C] 給水ノル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/3/26 0:00	0.03	4589	29.3	4	45.8	105	-50	28
2011/3/26 1:00	0.03	4589	29.3	4	45.2	105	-50	28
2011/3/26 2:00	0.03	4589	29.2	4	45.1	105	-50	28
2011/3/26 3:00	0.03	4589	29.2	4	45.0	105	-50	28
2011/3/26 4:00	0.03	4589	29.2	4	45.0	105	-50	28
2011/3/26 5:00	0.03	4589	29.2	4	45.0	105	-51	28
2011/3/26 6:00	0.03	4589	29.1	4	44.9	105	-50	28
2011/3/26 7:00	0.03	4589	29.1	4	44.9	105	-50	28
2011/3/26 8:00	0.03	4589	29.1	4	45.0	105	-51	28
2011/3/26 9:00	0.03	4589	29.1	4	45.0	105	-50	28
2011/3/26 10:00	0.03	4589	29.0	4	45.2	105	-51	28
2011/3/26 11:00	0.03	4589	29.0	4	45.0	105	-50	27
2011/3/26 12:00	0.03	4589	29.0	4	44.6	105	-50	27
2011/3/26 13:00	0.03	4589	29.0	4	44.5	105	-51	27
2011/3/26 14:00	0.03	4589	29.0	4	44.5	105	-51	27
2011/3/26 15:00	0.03	4589	29.0	4	44.3	105	-52	27
2011/3/26 16:00	0.03	4589	28.9	4	44.3	105	-51	27
2011/3/26 17:00	0.03	4589	28.9	3	44.2	105	-51	27
2011/3/26 18:00	0.03	4589	28.9	3	44.4	105	-50	27
2011/3/26 19:00	0.03	4589	28.9	3	44.4	105	-50	27
2011/3/26 20:00	0.03	4589	28.9	3	44.2	105	-50	27
2011/3/26 21:00	0.03	4589	28.8	3	44.1	105	-49	27
2011/3/26 22:00	0.03	4589	28.9	3	44.0	105	-49	27
2011/3/26 23:00	0.03	4589	28.8	3	44.1	104	-49	27
2011/3/27 0:00	0.03	4589	28.8	3	44.2	105	-50	27
2011/3/27 1:00	0.03	4589	28.8	3	44.3	104	-50	27
2011/3/27 2:00	0.03	4589	28.8	3	44.3	104	-50	27
2011/3/27 3:00	0.03	4589	28.8	3	44.3	105	-50	27
2011/3/27 4:00	0.03	4589	28.8	3	44.3	104	-50	27
2011/3/27 5:00	0.03	4589	28.8	2	44.2	104	-49	27
2011/3/27 6:00	0.03	4589	28.7	2	44.1	104	-49	27
2011/3/27 7:00	0.03	4589	28.8	2	44.0	104	-48	27
2011/3/27 8:00	0.03	4589	28.7	2	44.0	104	-48	27
2011/3/27 9:00	0.03	4589	28.6	2	44.0	104	-48	27
2011/3/27 10:00	0.03	4589	28.6	2	43.9	104	-48	27
2011/3/27 12:00	0.03	4589	28.6	2	43.3	104	-36	27
2011/3/27 14:00								
2011/3/27 16:00								
2011/3/27 18:00								
2011/3/27 20:00								
2011/3/27 22:00								
2011/3/28 0:00								

17/
22

2F-1号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa (gage)]	炉水位 [mm] 停止時	炉水温度[°C] 給水/スル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/3/26 0:00	0.05	5000	29.4	5	40.5	107	1004	25
2011/3/26 1:00	0.05	5000	29.3	5	40.5	107	1004	25
2011/3/26 2:00	0.05	5000	29.3	5	40.5	105	1004	25
2011/3/26 3:00	0.05	5000	29.3	5	40.4	107	1002	25
2011/3/26 4:00	0.05	5000	29.3	5	40.4	107	1002	25
2011/3/26 5:00	0.05	5000	29.2	5	40.5	107	1002	25
2011/3/26 6:00	0.05	5000	29.2	5	40.4	107	1003	25
2011/3/26 7:00	0.05	5000	29.2	5	40.3	107	1004	25
2011/3/26 8:00	0.05	5000	29.1	5	40.2	107	1002	25
2011/3/26 9:00	0.05	5000	29.1	5	40.2	107	1002	25
2011/3/26 10:00	0.05	5000	29.1	5	40.2	107	1002	25
2011/3/26 11:00	0.05	5000	29.1	5	40.1	107	1002	25
2011/3/26 12:00	0.05	4950	29.0	5	40.1	107	1002	25
2011/3/26 13:00	0.05	4950	29.0	5	40.1	107	1002	25
2011/3/26 14:00	0.05	4950	29.0	5	39.9	107	1002	25
2011/3/26 15:00	0.05	4950	29.0	5	39.9	107	1002	25
2011/3/26 16:00	0.05	4950	28.9	5	39.9	107	1002	25
2011/3/26 17:00	0.05	4950	29.0	5	39.8	107	1002	25
2011/3/26 18:00	0.05	4950	28.9	4	39.7	107	1002	25
2011/3/26 19:00	0.05	4950	28.9	4	39.7	107	1002	25
2011/3/26 20:00	0.05	4950	28.9	4	39.6	107	1002	25
2011/3/26 21:00	0.05	4950	28.9	4	39.6	107	1002	25
2011/3/26 22:00	0.05	4950	28.8	4	39.5	107	1002	25
2011/3/26 23:00	0.05	5050	28.8	4	39.5	107	996	25
2011/3/27 0:00	0.05	5050	28.8	4	39.5	107	994	25
2011/3/27 1:00	0.05	5050	28.7	4	39.4	107	994	25
2011/3/27 2:00	0.05	5050	28.7	4	39.4	107	994	25
2011/3/27 3:00	0.05	5050	28.7	4	39.4	107	992	25
2011/3/27 4:00	0.05	5050	28.6	4	39.3	107	992	25
2011/3/27 5:00	0.05	5050	28.6	4	39.1	107	992	24
2011/3/27 6:00	0.05	5050	28.6	4	39.2	107	993	24
2011/3/27 7:00	0.05	5050	28.5	4	39.2	107	992	24
2011/3/27 8:00	0.05	5050	28.5	4	39.2	107	993	24
2011/3/27 9:00	0.05	5100	28.5	4	39.0	107	993	25
2011/3/27 10:00	0.05	5100	28.4	4	39.0	107	993	25
2011/3/27 12:00	0.05	5100	28.3	4	39.0	105	993	25
2011/3/27 14:00	0.05	5100	28.3	4	38.8	107	993	25
2011/3/27 16:00								
2011/3/27 18:00								
2011/3/27 20:00								
2011/3/27 22:00								
2011/3/28 0:00								

18/22

2F-2号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa (gage)]	炉水位 [mm] 停止時	炉水温度[°C] 給水/スル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/3/26 0:00	0.02	6050	28.9	5.3	42.7	106	402	26
2011/3/26 1:00	0.02	6050	28.9	5.5	42.6	107	402	26
2011/3/26 2:00	0.02	6050	28.9	5.6	42.6	107	402	26
2011/3/26 3:00	0.03	6050	28.9	5.8	42.6	106	402	26
2011/3/26 4:00	0.03	6050	28.9	5.6	42.6	106	402	26
2011/3/26 5:00	0.02	6050	28.8	5.6	42.5	106	400	26
2011/3/26 6:00	0.03	6050	28.8	5.5	42.3	107	401	26
2011/3/26 7:00	0.03	6050	28.8	5.5	42.3	107	401	26
2011/3/26 8:00	0.02	6050	28.8	5.4	42.3	107	402	26
2011/3/26 9:00	0.02	6050	28.9	5.3	42.3	106	402	26
2011/3/26 10:00	0.03	6050	28.8	5.2	42.2	106	402	26
2011/3/26 11:00	0.03	6050	28.8	5.2	42.2	106	402	26
2011/3/26 12:00	0.03	6050	28.8	5.2	42.2	106	402	26
2011/3/26 13:00	0.03	6050	28.7	5.2	42.2	108	402	26
2011/3/26 14:00	0.03	6050	28.6	5.1	42.0	106	402	26
2011/3/26 15:00	0.03	6050	28.7	5.1	42.0	106	402	26
2011/3/26 16:00	0.03	6050	28.7	5.0	41.9	106	402	26
2011/3/26 17:00	0.02	6050	28.7	4.8	42.0	106	402	26
2011/3/26 18:00	0.02	6050	28.5	4.7	41.9	106	402	26
2011/3/26 19:00	0.02	6050	28.7	4.6	41.7	106	402	26
2011/3/26 20:00	0.03	6050	28.6	4.4	41.6	106	402	26
2011/3/26 21:00	0.03	6050	28.7	4.4	41.6	106	402	26
2011/3/26 22:00	0.02	6050	28.6	4.3	41.5	106	402	26
2011/3/26 23:00	0.03	6200	28.6	4.4	41.6	106	396	26
2011/3/27 0:00	0.03	6150	28.6	4.5	41.6	106	401	26
2011/3/27 1:00	0.03	6150	28.7	4.6	41.5	108	401	26
2011/3/27 2:00	0.02	6150	28.6	4.6	41.5	106	400	26
2011/3/27 3:00	0.03	6150	28.6	4.7	41.5	107	400	26
2011/3/27 4:00	0.03	6150	28.5	4.7	41.4	106	400	26
2011/3/27 5:00	0.03	6150	28.6	4.6	41.3	106	400	26
2011/3/27 6:00	0.03	6150	28.7	4.6	41.3	107	401	26
2011/3/27 7:00	0.03	6150	28.6	4.6	41.3	106	401	26
2011/3/27 8:00	0.03	6150	28.6	4.6	41.3	107	400	26
2011/3/27 9:00	0.03	6150	28.7	4.5	41.3	107	400	26
2011/3/27 10:00	0.03	6150	28.7	4.5	41.3	107	401	26
2011/3/27 12:00	0.02	6100	28.6	4.6	41.0	107	401	26
2011/3/27 14:00	0.03	6100	28.7	4.6	40.9	107	402	26
2011/3/27 16:00								
2011/3/27 18:00								
2011/3/27 20:00								
2011/3/27 22:00								
2011/3/28 0:00								

2F-3号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

19/22

時間	炉圧 [MPa (gage)]	炉水位 [mm] アッパセット	炉水温度[°C] 給水/スル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/3/26 0:00	0.01	4333	33.8	2	40.9	104	-19	26
2011/3/26 1:00	0.01	4337	33.8	2	40.6	104	-20	26
2011/3/26 2:00	0.01	4337	33.7	2	40.7	104	-20	26
2011/3/26 3:00	0.01	4337	33.7	3	40.6	104	-20	26
2011/3/26 4:00	0.01	4337	33.7	3	40.6	104	-20	26
2011/3/26 5:00	0.01	4337	33.7	3	40.6	104	-20	26
2011/3/26 6:00	0.01	4331	33.6	2	40.5	104	-19	26
2011/3/26 7:00	0.01	4330	33.6	2	40.5	104	-19	26
2011/3/26 8:00	0.01	4340	33.6	2	40.5	104	-19	26
2011/3/26 9:00	0.01	4344	33.5	2	40.5	104	-19	26
2011/3/26 10:00	0.01	4344	33.4	2	40.4	104	-20	26
2011/3/26 11:00	0.01	4344	33.4	2	40.4	104	-20	26
2011/3/26 12:00	0.01	4344	33.4	2	40.3	103	-20	26
2011/3/26 13:00	0.01	4347	33.4	2	40.4	103	-20	26
2011/3/26 14:00	0.01	4348	33.4	2	40.3	103	-20	26
2011/3/26 15:00	0.01	4348	33.4	2	40.2	103	-21	26
2011/3/26 16:00	0.01	4347	33.3	2	40.2	103	-20	26
2011/3/26 17:00	0.01	4350	33.3	2	40.1	103	-20	26
2011/3/26 18:00	0.01	4352	33.3	2	40.1	103	-20	26
2011/3/26 19:00	0.01	4352	33.3	2	40.1	103	-20	26
2011/3/26 20:00	0.01	4355	33.3	1	40.1	103	-20	26
2011/3/26 21:00	0.01	4355	33.2	1	40.0	103	-21	26
2011/3/26 22:00	0.01	4355	33.2	1	40.0	103	-20	26
2011/3/26 23:00	0.01	4358	33.2	1	40.0	103	-20	26
2011/3/27 0:00	0.01	4359	33.2	1	40.0	103	-20	26
2011/3/27 1:00	0.01	4361	33.2	1	39.9	103	-21	26
2011/3/27 2:00	0.01	4359	33.1	1	39.9	103	-21	26
2011/3/27 3:00	0.01	4362	33.1	1	39.9	103	-21	26
2011/3/27 4:00	0.01	4365	33.0	1	39.8	103	-21	26
2011/3/27 5:00	0.01	4361	33.0	1	39.7	103	-21	26
2011/3/27 6:00	0.01	4355	33.0	1	39.7	103	-21	26
2011/3/27 7:00	0.01	4354	32.9	1	39.7	103	-21	26
2011/3/27 8:00	0.01	4354	32.9	1	39.7	103	-21	26
2011/3/27 9:00	0.01	4357	32.9	1	39.6	103	-21	26
2011/3/27 10:00	0.01	4354	32.8	1	39.5	103	-21	26
2011/3/27 12:00	0.00	3642	36.0	1	39.5	104	17	26
2011/3/27 14:00	0.00	3684	47.5	2	40.0	103	16	26
2011/3/27 16:00								
2011/3/27 18:00								
2011/3/27 20:00								
2011/3/27 22:00								
2011/3/28 0:00								

炉水位、炉水温度、S/Cの水位の変動は、S/C運転モードを変更による。

20/22

2F-4号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa (gage)]	炉水位 [mm] 777セット	炉水温度[°C] 給水/スル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/3/26 0:00	0.03	4589	29.3	4	45.8	105	-50	28
2011/3/26 1:00	0.03	4589	29.3	4	45.2	105	-50	28
2011/3/26 2:00	0.03	4589	29.2	4	45.1	105	-50	28
2011/3/26 3:00	0.03	4589	29.2	4	45.0	105	-50	28
2011/3/26 4:00	0.03	4589	29.2	4	45.0	105	-50	28
2011/3/26 5:00	0.03	4589	29.2	4	45.0	105	-51	28
2011/3/26 6:00	0.03	4589	29.1	4	44.9	105	-50	28
2011/3/26 7:00	0.03	4589	29.1	4	44.9	105	-50	28
2011/3/26 8:00	0.03	4589	29.1	4	45.0	105	-51	28
2011/3/26 9:00	0.03	4589	29.1	4	45.0	105	-50	28
2011/3/26 10:00	0.03	4589	29.0	4	45.2	105	-51	28
2011/3/26 11:00	0.03	4589	29.0	4	45.0	105	-50	27
2011/3/26 12:00	0.03	4589	29.0	4	44.6	105	-50	27
2011/3/26 13:00	0.03	4589	29.0	4	44.5	105	-51	27
2011/3/26 14:00	0.03	4589	29.0	4	44.5	105	-51	27
2011/3/26 15:00	0.03	4589	29.0	4	44.3	105	-52	27
2011/3/26 16:00	0.03	4589	28.9	4	44.3	105	-51	27
2011/3/26 17:00	0.03	4589	28.9	3	44.2	105	-51	27
2011/3/26 18:00	0.03	4589	28.9	3	44.4	105	-50	27
2011/3/26 19:00	0.03	4589	28.9	3	44.4	105	-50	27
2011/3/26 20:00	0.03	4589	28.9	3	44.2	105	-50	27
2011/3/26 21:00	0.03	4589	28.8	3	44.1	105	-49	27
2011/3/26 22:00	0.03	4589	28.9	3	44.0	105	-49	27
2011/3/26 23:00	0.03	4589	28.8	3	44.1	104	-49	27
2011/3/27 0:00	0.03	4589	28.8	3	44.2	105	-50	27
2011/3/27 1:00	0.03	4589	28.8	3	44.3	104	-50	27
2011/3/27 2:00	0.03	4589	28.8	3	44.3	104	-50	27
2011/3/27 3:00	0.03	4589	28.8	3	44.3	105	-50	27
2011/3/27 4:00	0.03	4589	28.8	3	44.3	104	-50	27
2011/3/27 5:00	0.03	4589	28.8	2	44.2	104	-49	27
2011/3/27 6:00	0.03	4589	28.7	2	44.1	104	-49	27
2011/3/27 7:00	0.03	4589	28.8	2	44.0	104	-48	27
2011/3/27 8:00	0.03	4589	28.7	2	44.0	104	-48	27
2011/3/27 9:00	0.03	4589	28.6	2	44.0	104	-48	27
2011/3/27 10:00	0.03	4589	28.6	2	43.9	104	-48	27
2011/3/27 12:00	0.03	4589	28.6	2	43.3	104	-36	27
2011/3/27 14:00	0.03	4589	28.5	2	43.3	104	-36	27
2011/3/27 16:00								
2011/3/27 18:00								
2011/3/27 20:00								
2011/3/27 22:00								
2011/3/28 0:00								

2F-1号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa (gage)]	炉水位 [mm] 停止時	炉水温度[°C] 給水ノズル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/3/27 0:00	0.05	5050	28.8	4	39.5	107	994	25
2011/3/27 1:00	0.05	5050	28.7	4	39.4	107	994	25
2011/3/27 2:00	0.05	5050	28.7	4	39.4	107	994	25
2011/3/27 3:00	0.05	5050	28.7	4	39.4	107	992	25
2011/3/27 4:00	0.05	5050	28.6	4	39.3	107	992	25
2011/3/27 5:00	0.05	5050	28.6	4	39.1	107	992	24
2011/3/27 6:00	0.05	5050	28.6	4	39.2	107	993	24
2011/3/27 7:00	0.05	5050	28.5	4	39.2	107	992	24
2011/3/27 8:00	0.05	5050	28.5	4	39.2	107	993	24
2011/3/27 9:00	0.05	5100	28.5	4	39.0	107	993	25
2011/3/27 10:00	0.05	5100	28.4	4	39.0	107	993	25
2011/3/27 12:00	0.05	5100	28.3	4	39.0	105	993	25
2011/3/27 14:00	0.05	5100	28.3	4	38.8	107	993	25
2011/3/27 16:00	0.05	5100	28.3	4	38.8	107	993	25
2011/3/27 18:00	0.05	5100	28.2	4	38.8	107	993	24
2011/3/27 20:00								
2011/3/27 22:00								
2011/3/28 0:00								
2011/3/28 2:00								
2011/3/28 4:00								
2011/3/28 6:00								
2011/3/28 8:00								
2011/3/28 9:00								
2011/3/28 10:00								
2011/3/28 12:00								

2F-2号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa (gage)]	炉水位 [mm] 停止時	炉水温度[°C] 給水/スル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/3/27 0:00	0.03	6150	28.6	4.5	41.6	106	401	26
2011/3/27 1:00	0.03	6150	28.7	4.6	41.5	106	401	26
2011/3/27 2:00	0.02	6150	28.6	4.6	41.5	106	400	26
2011/3/27 3:00	0.03	6150	28.6	4.7	41.5	107	400	26
2011/3/27 4:00	0.03	6150	28.5	4.7	41.4	106	400	26
2011/3/27 5:00	0.03	6150	28.6	4.6	41.3	106	400	26
2011/3/27 6:00	0.03	6150	28.7	4.6	41.3	107	401	26
2011/3/27 7:00	0.03	6150	28.6	4.6	41.3	106	401	26
2011/3/27 8:00	0.03	6150	28.6	4.6	41.3	107	400	26
2011/3/27 9:00	0.03	6150	28.7	4.5	41.3	107	400	26
2011/3/27 10:00	0.03	6150	28.7	4.5	41.3	107	401	26
2011/3/27 12:00	0.02	6100	28.6	4.6	41.0	107	401	26
2011/3/27 14:00	0.03	6100	28.7	4.6	40.9	107	402	26
2011/3/27 16:00	0.03	6100	28.8	4.5	41.0	106	402	26
2011/3/27 18:00	0.03	6100	28.6	4.4	40.8	106	402	26
2011/3/27 20:00								
2011/3/27 22:00								
2011/3/28 0:00								
2011/3/28 2:00								
2011/3/28 4:00								
2011/3/28 6:00								
2011/3/28 8:00								
2011/3/28 9:00								
2011/3/28 10:00								
2011/3/28 12:00								

2F-3号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa (gage)]	炉水位 [mm] アップセット	炉水温度[°C] 給水ノズル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/3/27 0:00	0.01	4359	33.2	1	40.0	103	-20	26
2011/3/27 1:00	0.01	4361	33.2	1	39.9	103	-21	26
2011/3/27 2:00	0.01	4359	33.1	1	39.9	103	-21	26
2011/3/27 3:00	0.01	4362	33.1	1	39.9	103	-21	26
2011/3/27 4:00	0.01	4365	33.0	1	39.8	103	-21	26
2011/3/27 5:00	0.01	4361	33.0	1	39.7	103	-21	26
2011/3/27 6:00	0.01	4355	33.0	1	39.7	103	-21	26
2011/3/27 7:00	0.01	4354	32.9	1	39.7	103	-21	26
2011/3/27 8:00	0.01	4354	32.9	1	39.7	103	-21	26
2011/3/27 9:00	0.01	4357	32.9	1	39.6	103	-21	26
2011/3/27 10:00	0.01	4354	32.8	1	39.5	103	-21	26
2011/3/27 12:00	0.00	3642	36.0	1	39.5	104	17	26
2011/3/27 14:00	0.00	3684	47.5	2	40.0	103	16	26
2011/3/27 16:00	0.00	3676	48.2	2	40.5	104	16	26
2011/3/27 18:00	0.00	3670	47.2	1	40.7	103	17	26
2011/3/27 20:00								
2011/3/27 22:00								
2011/3/28 0:00								
2011/3/28 2:00								
2011/3/28 4:00								
2011/3/28 6:00								
2011/3/28 8:00								
2011/3/28 9:00								
2011/3/28 10:00								
2011/3/28 12:00								

炉水位、炉水温度、S/Cの水位の変動は、S/C運転モードを変更による。

2F-4号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa (gage)]	炉水位 [mm] アップセット	炉水温度[°C] 給水/スル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/3/27 0:00	0.03	4589	28.8	3	44.2	105	-50	27
2011/3/27 1:00	0.03	4589	28.8	3	44.3	104	-50	27
2011/3/27 2:00	0.03	4589	28.8	3	44.3	104	-50	27
2011/3/27 3:00	0.03	4589	28.8	3	44.3	105	-50	27
2011/3/27 4:00	0.03	4589	28.8	3	44.3	104	-50	27
2011/3/27 5:00	0.03	4589	28.8	2	44.2	104	-49	27
2011/3/27 6:00	0.03	4589	28.7	2	44.1	104	-49	27
2011/3/27 7:00	0.03	4589	28.8	2	44.0	104	-48	27
2011/3/27 8:00	0.03	4589	28.7	2	44.0	104	-48	27
2011/3/27 9:00	0.03	4589	28.6	2	44.0	104	-48	27
2011/3/27 10:00	0.03	4589	28.6	2	43.9	104	-48	27
2011/3/27 12:00	0.03	4589	28.6	2	43.3	104	-36	27
2011/3/27 14:00	0.03	4589	28.5	2	43.3	104	-36	27
2011/3/27 16:00	0.03	4589	28.5	2	43.5	104	-36	27
2011/3/27 18:00	0.03	4589	28.4	2	43.5	104	-36	27
2011/3/27 20:00								
2011/3/27 22:00								
2011/3/28 0:00								
2011/3/28 2:00								
2011/3/28 4:00								
2011/3/28 6:00								
2011/3/28 8:00								
2011/3/28 9:00								
2011/3/28 10:00								
2011/3/28 12:00								