




# 2F-1号機




# 2F-2号機



# 2F-3号機



# 2F-4号機







# 2F-3号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa (gage)]	炉水位 [mm] アッパセット	炉水温度[°C] 給水/スル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/4/20 0:00	0.00	3597	33.2	11	34.3	110	2100	26
2011/4/20 2:00	0.00	3597	33.1	11	34.3	110	2100	26
2011/4/20 4:00	0.00	3597	33.0	11	34.0	111	2100	26
2011/4/20 6:00	0.00	3596	32.9	10	34.0	110	2100	26
2011/4/20 8:00	0.00	3596	32.8	10	34.0	110	2100	26
2011/4/20 10:00	0.00	3596	32.7	10	34.0	111	2100	26
2011/4/20 12:00	0.00	3596	32.7	10	33.9	111	2100	26
2011/4/20 14:00	0.00	3596	32.7	10	33.9	111	2100	26
2011/4/20 16:00	0.00	3594	32.7	9	33.9	110	2100	26
2011/4/20 18:00	0.00	3593	32.8	9	33.9	110	2100	26
2011/4/20 20:00	0.00	3593	32.8	9	33.9	110	2100	26
2011/4/20 22:00	0.00	3593	32.8	9	33.9	110	2100	26
2011/4/21 0:00	0.00	3593	32.8	9	33.9	110	2100	26
2011/4/21 2:00	0.00	3593	32.8	9	33.8	110	2100	26
<b>2011/4/21 4:00</b>	<b>0.00</b>	<b>3593</b>	<b>32.8</b>	<b>9</b>	<b>33.9</b>	<b>110</b>	<b>2100</b>	<b>26</b>
2011/4/21 6:00								
2011/4/21 8:00								
2011/4/21 10:00								
2011/4/21 12:00								
2011/4/21 14:00								
2011/4/21 16:00								
2011/4/21 18:00								
2011/4/21 20:00								
2011/4/21 22:00								
2011/4/22 0:00								
2011/4/22 2:00								
2011/4/22 4:00								
2011/4/22 6:00								
2011/4/22 8:00								
2011/4/22 10:00								
2011/4/22 12:00								
2011/4/22 14:00								
2011/4/22 16:00								
2011/4/22 18:00								
2011/4/22 20:00								
2011/4/22 22:00								
2011/4/23 0:00								

# 2F-4号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa (gage)]	炉水位 [mm] アッブセット	炉水温度[°C] 給水ノズル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/4/20 0:00	0.07	4589	28.8	7	33.3	107	2050	29
2011/4/20 2:00	0.07	4589	28.8	7	33.3	107	2000	29
2011/4/20 4:00	0.07	4589	28.8	7	33.3	107	2000	29
2011/4/20 6:00	0.07	4589	28.7	7	32.9	107	2000	29
2011/4/20 8:00	0.07	4589	28.6	6	32.8	107	2050	29
2011/4/20 10:00	0.07	4589	28.5	6	33.0	107	2050	29
2011/4/20 12:00	0.07	4589	28.5	6	33.1	106	2050	29
2011/4/20 14:00	0.07	4589	28.5	6	33.1	106	2050	29
2011/4/20 16:00	0.07	4589	28.5	6	33.2	107	2050	29
2011/4/20 18:00	0.07	4589	28.4	5	32.5	107	2000	29
2011/4/20 20:00	0.07	4589	28.4	5	32.5	107	2000	29
2011/4/20 22:00	0.07	4589	28.4	5	32.9	107	2050	29
2011/4/21 0:00	0.07	4589	28.3	5	32.4	107	2050	29
2011/4/21 2:00	0.07	4589	28.3	5	32.4	107	2050	29
<b>2011/4/21 4:00</b>	<b>0.07</b>	<b>4589</b>	<b>28.2</b>	<b>5</b>	<b>32.5</b>	<b>107</b>	<b>2050</b>	<b>29</b>
2011/4/21 6:00								
2011/4/21 8:00								
2011/4/21 10:00								
2011/4/21 12:00								
2011/4/21 14:00								
2011/4/21 16:00								
2011/4/21 18:00								
2011/4/21 20:00								
2011/4/21 22:00								
2011/4/22 0:00								
2011/4/22 2:00								
2011/4/22 4:00								
2011/4/22 6:00								
2011/4/22 8:00								
2011/4/22 10:00								
2011/4/22 12:00								
2011/4/22 14:00								
2011/4/22 16:00								
2011/4/22 18:00								
2011/4/22 20:00								
2011/4/22 22:00								
2011/4/23 0:00								

2011年4月21日 0時47分 01771110 4月21日 0時47分 01771110



# 2F-1号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa (gage)]	炉水位 [mm] 停止時	炉水温度[°C] 給水ノズル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/4/20 0:00	0.05	5100	24.7	5	28.8	105	1435	24
2011/4/20 2:00	0.05	5150	24.7	5	29.0	105	1435	24
2011/4/20 4:00	0.05	5150	24.7	4	28.9	105	1435	24
2011/4/20 6:00	0.05	5150	24.6	4	28.8	105	1434	24
2011/4/20 8:00	0.05	5150	24.5	3	28.8	105	1436	24
2011/4/20 10:00	0.05	5150	24.5	3	28.8	105	1436	24
2011/4/20 12:00	0.05	5150	24.4	3	28.7	105	1433	23
2011/4/20 14:00	0.05	5150	24.4	3	28.8	105	1435	23
2011/4/20 16:00	0.05	5150	24.3	3	28.7	105	1436	23
2011/4/20 18:00	0.05	5150	24.3	2	28.7	105	1435	23
2011/4/20 20:00	0.05	5150	24.3	2	28.6	105	1434	23
2011/4/20 22:00	0.05	5150	24.3	2	28.7	105	1437	23
2011/4/21 0:00	0.05	5150	24.3	2	28.5	105	1437	23
2011/4/21 2:00	0.05	5150	24.3	2	28.6	105	1437	23
2011/4/21 4:00	0.05	5150	24.2	2	28.6	105	1437	23
<b>2011/4/21 6:00</b>	<b>0.05</b>	<b>5150</b>	<b>24.2</b>	<b>2</b>	<b>28.5</b>	<b>105</b>	<b>1437</b>	<b>23</b>
2011/4/21 8:00								
2011/4/21 10:00								
2011/4/21 12:00								
2011/4/21 14:00								
2011/4/21 16:00								
2011/4/21 18:00								
2011/4/21 20:00								
2011/4/21 22:00								
2011/4/22 0:00								
2011/4/22 2:00								
2011/4/22 4:00								
2011/4/22 6:00								
2011/4/22 8:00								
2011/4/22 10:00								
2011/4/22 12:00								
2011/4/22 14:00								
2011/4/22 16:00								
2011/4/22 18:00								
2011/4/22 20:00								
2011/4/22 22:00								
2011/4/23 0:00								

# 2F-2号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa (gage)]	炉水位 [mm] 停止時	炉水温度[°C] 給水/スル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/4/20 0:00	0.03	6100	24.6	4.6	30.1	104	1200	24
2011/4/20 2:00	0.04	6100	24.6	4.5	30.0	105	1200	24
2011/4/20 4:00	0.04	6100	24.6	4.5	30.0	105	1200	24
2011/4/20 6:00	0.04	6100	24.5	4.4	30.0	105	1200	24
2011/4/20 8:00	0.03	6100	24.3	3.7	30.0	104	1200	23
2011/4/20 10:00	0.04	6100	24.3	3.6	30.0	104	1200	24
2011/4/20 12:00	0.04	6100	24.2	3.4	30.0	104	1200	24
2011/4/20 14:00	0.04	6100	24.2	3.2	29.7	104	1200	23
2011/4/20 16:00	0.04	6050	24.2	3.1	29.9	104	1200	23
2011/4/20 18:00	0.04	6100	24.3	2.9	29.9	104	1200	23
2011/4/20 20:00	0.04	6100	24.3	2.7	29.9	104	1200	24
2011/4/20 22:00	0.04	6100	24.4	2.6	29.9	104	1200	24
2011/4/21 0:00	0.04	6100	24.4	2.5	29.9	104	1200	24
2011/4/21 2:00	0.04	6100	24.4	2.5	29.9	104	1200	24
2011/4/21 4:00	0.04	6100	24.4	2.4	29.9	104	1200	24
2011/4/21 6:00	0.04	6100	24.5	2.4	29.9	104	1200	24
2011/4/21 8:00								
2011/4/21 10:00								
2011/4/21 12:00								
2011/4/21 14:00								
2011/4/21 16:00								
2011/4/21 18:00								
2011/4/21 20:00								
2011/4/21 22:00								
2011/4/22 0:00								
2011/4/22 2:00								
2011/4/22 4:00								
2011/4/22 6:00								
2011/4/22 8:00								
2011/4/22 10:00								
2011/4/22 12:00								
2011/4/22 14:00								
2011/4/22 16:00								
2011/4/22 18:00								
2011/4/22 20:00								
2011/4/22 22:00								
2011/4/23 0:00								

NO. 1310 1. 24

水島川原町 原丁川上元 水産

2011年 4月21日 0時10分

# 2F-3号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa (gage)]	炉水位 [mm] アップセット	炉水温度[°C] 給水/スル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/4/20 0:00	0.00	3597	33.2	11	34.3	110	2100	26
2011/4/20 2:00	0.00	3597	33.1	11	34.3	110	2100	26
2011/4/20 4:00	0.00	3597	33.0	11	34.0	111	2100	26
2011/4/20 6:00	0.00	3596	32.9	10	34.0	110	2100	26
2011/4/20 8:00	0.00	3596	32.8	10	34.0	110	2100	26
2011/4/20 10:00	0.00	3596	32.7	10	34.0	111	2100	26
2011/4/20 12:00	0.00	3596	32.7	10	33.9	111	2100	26
2011/4/20 14:00	0.00	3596	32.7	10	33.9	111	2100	26
2011/4/20 16:00	0.00	3594	32.7	9	33.9	110	2100	26
2011/4/20 18:00	0.00	3593	32.8	9	33.9	110	2100	26
2011/4/20 20:00	0.00	3593	32.8	9	33.9	110	2100	26
2011/4/20 22:00	0.00	3593	32.8	9	33.9	110	2100	26
2011/4/21 0:00	0.00	3593	32.8	9	33.9	110	2100	26
2011/4/21 2:00	0.00	3593	32.8	9	33.8	110	2100	26
2011/4/21 4:00	0.00	3593	32.8	9	33.9	110	2100	26
2011/4/21 6:00	0.00	3593	32.9	9	33.8	110	2100	26
2011/4/21 8:00								
2011/4/21 10:00								
2011/4/21 12:00								
2011/4/21 14:00								
2011/4/21 16:00								
2011/4/21 18:00								
2011/4/21 20:00								
2011/4/21 22:00								
2011/4/22 0:00								
2011/4/22 2:00								
2011/4/22 4:00								
2011/4/22 6:00								
2011/4/22 8:00								
2011/4/22 10:00								
2011/4/22 12:00								
2011/4/22 14:00								
2011/4/22 16:00								
2011/4/22 18:00								
2011/4/22 20:00								
2011/4/22 22:00								
2011/4/23 0:00								

# 2F-4号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa (gage)]	炉水位 [mm] アップセット	炉水温度[°C] 給水/スル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/4/20 0:00	0.07	4589	28.8	7	33.3	107	2050	29
2011/4/20 2:00	0.07	4589	28.8	7	33.3	107	2000	29
2011/4/20 4:00	0.07	4589	28.8	7	33.3	107	2000	29
2011/4/20 6:00	0.07	4589	28.7	7	32.9	107	2000	29
2011/4/20 8:00	0.07	4589	28.6	6	32.8	107	2050	29
2011/4/20 10:00	0.07	4589	28.5	6	33.0	107	2050	29
2011/4/20 12:00	0.07	4589	28.5	6	33.1	106	2050	29
2011/4/20 14:00	0.07	4589	28.5	6	33.1	106	2050	29
2011/4/20 16:00	0.07	4589	28.5	6	33.2	107	2050	29
2011/4/20 18:00	0.07	4589	28.4	5	32.5	107	2000	29
2011/4/20 20:00	0.07	4589	28.4	5	32.5	107	2000	29
2011/4/20 22:00	0.07	4589	28.4	5	32.9	107	2050	29
2011/4/21 0:00	0.07	4589	28.3	5	32.4	107	2050	29
2011/4/21 2:00	0.07	4589	28.3	5	32.4	107	2050	29
2011/4/21 4:00	0.07	4589	28.2	5	32.5	107	2050	29
2011/4/21 6:00	0.07	4589	28.2	5	32.1	107	2050	29
2011/4/21 8:00								
2011/4/21 10:00								
2011/4/21 12:00								
2011/4/21 14:00								
2011/4/21 16:00								
2011/4/21 18:00								
2011/4/21 20:00								
2011/4/21 22:00								
2011/4/22 0:00								
2011/4/22 2:00								
2011/4/22 4:00								
2011/4/22 6:00								
2011/4/22 8:00								
2011/4/22 10:00								
2011/4/22 12:00								
2011/4/22 14:00								
2011/4/22 16:00								
2011/4/22 18:00								
2011/4/22 20:00								
2011/4/22 22:00								
2011/4/23 0:00								

2011年 4月 7日 0時 10分  
 東京電力(株) 原子力発電部  
 東京電力(株) 原子力発電部

4196

2F-1号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa (gage)]	炉水位 [mm] 停止時	炉水温度[°C] 給水/スル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/4/20 0:00	0.05	5100	24.7	5	28.8	105	1435	24
2011/4/20 2:00	0.05	5150	24.7	5	29.0	105	1435	24
2011/4/20 4:00	0.05	5150	24.7	4	28.9	105	1435	24
2011/4/20 6:00	0.05	5150	24.6	4	28.8	105	1434	24
2011/4/20 8:00	0.05	5150	24.5	3	28.8	105	1436	24
2011/4/20 10:00	0.05	5150	24.5	3	28.8	105	1436	24
2011/4/20 12:00	0.05	5150	24.4	3	28.7	105	1433	23
2011/4/20 14:00	0.05	5150	24.4	3	28.8	105	1435	23
2011/4/20 16:00	0.05	5150	24.3	3	28.7	105	1436	23
2011/4/20 18:00	0.05	5150	24.3	2	28.7	105	1435	23
2011/4/20 20:00	0.05	5150	24.3	2	28.6	105	1434	23
2011/4/20 22:00	0.05	5150	24.3	2	28.7	105	1437	23
2011/4/21 0:00	0.05	5150	24.3	2	28.5	105	1437	23
2011/4/21 2:00	0.05	5150	24.3	2	28.6	105	1437	23
2011/4/21 4:00	0.05	5150	24.2	2	28.6	105	1437	23
2011/4/21 6:00	0.05	5150	24.2	2	28.5	105	1437	23
2011/4/21 8:00	0.05	5150	24.2	2	28.5	105	1437	23
2011/4/21 10:00	0.05	5150	24.2	2	28.5	105	1436	23
<b>2011/4/21 12:00</b>	<b>0.05</b>	<b>5150</b>	<b>24.2</b>	<b>2</b>	<b>28.4</b>	<b>105</b>	<b>1437</b>	<b>23</b>
2011/4/21 14:00								
2011/4/21 16:00								
2011/4/21 18:00								
2011/4/21 20:00								
2011/4/21 22:00								
2011/4/22 0:00								
2011/4/22 2:00								
2011/4/22 4:00								
2011/4/22 6:00								
2011/4/22 8:00								
2011/4/22 10:00								
2011/4/22 12:00								
2011/4/22 14:00								
2011/4/22 16:00								
2011/4/22 18:00								
2011/4/22 20:00								
2011/4/22 22:00								
2011/4/23 0:00								

### 2F-2号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa (gage)]	炉水位 [mm] 停止時	炉水温度[°C] 給水ノズル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/4/20 0:00	0.03	6100	24.6	4.6	30.1	104	1200	24
2011/4/20 2:00	0.04	6100	24.6	4.5	30.0	105	1200	24
2011/4/20 4:00	0.04	6100	24.6	4.5	30.0	105	1200	24
2011/4/20 6:00	0.04	6100	24.5	4.4	30.0	105	1200	24
2011/4/20 8:00	0.03	6100	24.3	3.7	30.0	104	1200	23
2011/4/20 10:00	0.04	6100	24.3	3.6	30.0	104	1200	24
2011/4/20 12:00	0.04	6100	24.2	3.4	30.0	104	1200	24
2011/4/20 14:00	0.04	6100	24.2	3.2	29.7	104	1200	23
2011/4/20 16:00	0.04	6050	24.2	3.1	29.9	104	1200	23
2011/4/20 18:00	0.04	6100	24.3	2.9	29.9	104	1200	23
2011/4/20 20:00	0.04	6100	24.3	2.7	29.9	104	1200	24
2011/4/20 22:00	0.04	6100	24.4	2.6	29.9	104	1200	24
2011/4/21 0:00	0.04	6100	24.4	2.5	29.9	104	1200	24
2011/4/21 2:00	0.04	6100	24.4	2.5	29.9	104	1200	24
2011/4/21 4:00	0.04	6100	24.4	2.4	29.9	104	1200	24
2011/4/21 6:00	0.04	6100	24.5	2.4	29.9	104	1200	24
2011/4/21 8:00	0.03	6100	24.5	2.4	29.9	104	1200	24
2011/4/21 10:00	0.03	6100	24.5	2.4	29.9	104	1200	24
<b>2011/4/21 12:00</b>	<b>0.03</b>	<b>6100</b>	<b>24.5</b>	<b>2.4</b>	<b>29.7</b>	<b>104</b>	<b>1200</b>	<b>24</b>
2011/4/21 14:00								
2011/4/21 16:00								
2011/4/21 18:00								
2011/4/21 20:00								
2011/4/21 22:00								
2011/4/22 0:00								
2011/4/22 2:00								
2011/4/22 4:00								
2011/4/22 6:00								
2011/4/22 8:00								
2011/4/22 10:00								
2011/4/22 12:00								
2011/4/22 14:00								
2011/4/22 16:00								
2011/4/22 18:00								
2011/4/22 20:00								
2011/4/22 22:00								
2011/4/23 0:00								

# 2F-3号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa (gage)]	炉水位 [mm] アップセット	炉水温度[°C] 給水/スル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/4/20 0:00	0.00	3597	33.2	11	34.3	110	2100	26
2011/4/20 2:00	0.00	3597	33.1	11	34.3	110	2100	26
2011/4/20 4:00	0.00	3597	33.0	11	34.0	111	2100	26
2011/4/20 6:00	0.00	3596	32.9	10	34.0	110	2100	26
2011/4/20 8:00	0.00	3596	32.8	10	34.0	110	2100	26
2011/4/20 10:00	0.00	3596	32.7	10	34.0	111	2100	26
2011/4/20 12:00	0.00	3596	32.7	10	33.9	111	2100	26
2011/4/20 14:00	0.00	3596	32.7	10	33.9	111	2100	26
2011/4/20 16:00	0.00	3594	32.7	9	33.9	110	2100	26
2011/4/20 18:00	0.00	3593	32.8	9	33.9	110	2100	26
2011/4/20 20:00	0.00	3593	32.8	9	33.9	110	2100	26
2011/4/20 22:00	0.00	3593	32.8	9	33.9	110	2100	26
2011/4/21 0:00	0.00	3593	32.8	9	33.9	110	2100	26
2011/4/21 2:00	0.00	3593	32.8	9	33.8	110	2100	26
2011/4/21 4:00	0.00	3593	32.8	9	33.9	110	2100	26
2011/4/21 6:00	0.00	3593	32.9	9	33.8	110	2100	26
2011/4/21 8:00	0.00	3593	32.8	9	33.7	110	2100	26
2011/4/21 10:00	0.00	3593	32.8	9	33.7	110	2100	26
2011/4/21 12:00	0.00	3593	32.8	9	33.8	110	2100	26
2011/4/21 14:00								
2011/4/21 16:00								
2011/4/21 18:00								
2011/4/21 20:00								
2011/4/21 22:00								
2011/4/22 0:00								
2011/4/22 2:00								
2011/4/22 4:00								
2011/4/22 6:00								
2011/4/22 8:00								
2011/4/22 10:00								
2011/4/22 12:00								
2011/4/22 14:00								
2011/4/22 16:00								
2011/4/22 18:00								
2011/4/22 20:00								
2011/4/22 22:00								
2011/4/23 0:00								

# 2F-4号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa (gage)]	炉水位 [mm] アップセット	炉水温度[°C] 給水/スル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/4/20 0:00	0.07	4589	28.8	7	33.3	107	2050	29
2011/4/20 2:00	0.07	4589	28.8	7	33.3	107	2000	29
2011/4/20 4:00	0.07	4589	28.8	7	33.3	107	2000	29
2011/4/20 6:00	0.07	4589	28.7	7	32.9	107	2000	29
2011/4/20 8:00	0.07	4589	28.6	6	32.8	107	2050	29
2011/4/20 10:00	0.07	4589	28.5	6	33.0	107	2050	29
2011/4/20 12:00	0.07	4589	28.5	6	33.1	106	2050	29
2011/4/20 14:00	0.07	4589	28.5	6	33.1	106	2050	29
2011/4/20 16:00	0.07	4589	28.5	6	33.2	107	2050	29
2011/4/20 18:00	0.07	4589	28.4	5	32.5	107	2000	29
2011/4/20 20:00	0.07	4589	28.4	5	32.5	107	2000	29
2011/4/20 22:00	0.07	4589	28.4	5	32.9	107	2050	29
2011/4/21 0:00	0.07	4589	28.3	5	32.4	107	2050	29
2011/4/21 2:00	0.07	4589	28.3	5	32.4	107	2050	29
2011/4/21 4:00	0.07	4589	28.2	5	32.5	107	2050	29
2011/4/21 6:00	0.07	4589	28.2	5	32.1	107	2050	29
2011/4/21 8:00	0.07	4589	28.2	5	32.3	107	2050	29
2011/4/21 10:00	0.07	4598	28.2	5	32.6	107	2050	29
<b>2011/4/21 12:00</b>	<b>0.07</b>	<b>4598</b>	<b>28.1</b>	<b>5</b>	<b>32.9</b>	<b>107</b>	<b>2050</b>	<b>29</b>
2011/4/21 14:00								
2011/4/21 16:00								
2011/4/21 18:00								
2011/4/21 20:00								
2011/4/21 22:00								
2011/4/22 0:00								
2011/4/22 2:00								
2011/4/22 4:00								
2011/4/22 6:00								
2011/4/22 8:00								
2011/4/22 10:00								
2011/4/22 12:00								
2011/4/22 14:00								
2011/4/22 16:00								
2011/4/22 18:00								
2011/4/22 20:00								
2011/4/22 22:00								
2011/4/23 0:00								



# 2F-1号機

※燃料頂部(TAF)からの水位=炉水<sub>L</sub>+4200[mm]

時間	炉圧 [MPa (gage)]	炉水位 [mm] 停止時	炉水温度[°C] 給水/スル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/4/20 0:00	0.05	5100	24.7	5	28.8	105	1435	24
2011/4/20 2:00	0.05	5150	24.7	5	29.0	105	1435	24
2011/4/20 4:00	0.05	5150	24.7	4	28.9	105	1435	24
2011/4/20 6:00	0.05	5150	24.6	4	28.8	105	1434	24
2011/4/20 8:00	0.05	5150	24.5	3	28.8	105	1436	24
2011/4/20 10:00	0.05	5150	24.5	3	28.8	105	1436	24
2011/4/20 12:00	0.05	5150	24.4	3	28.7	105	1433	23
2011/4/20 14:00	0.05	5150	24.4	3	28.8	105	1435	23
2011/4/20 16:00	0.05	5150	24.3	3	28.7	105	1436	23
2011/4/20 18:00	0.05	5150	24.3	2	28.7	105	1435	23
2011/4/20 20:00	0.05	5150	24.3	2	28.6	105	1434	23
2011/4/20 22:00	0.05	5150	24.3	2	28.7	105	1437	23
2011/4/21 0:00	0.05	5150	24.3	2	28.5	105	1437	23
2011/4/21 2:00	0.05	5150	24.3	2	28.6	105	1437	23
2011/4/21 4:00	0.05	5150	24.2	2	28.6	105	1437	23
2011/4/21 6:00	0.05	5150	24.2	2	28.5	105	1437	23
2011/4/21 8:00	0.05	5150	24.2	2	28.5	105	1437	23
2011/4/21 10:00	0.05	5150	24.2	2	28.5	105	1436	23
2011/4/21 12:00	0.05	5150	24.2	2	28.4	105	1437	23
2011/4/21 14:00	0.05	5150	24.2	2	28.5	105	1435	23
2011/4/21 16:00	0.05	5150	24.2	2	28.6	105	1435	23
2011/4/21 18:00	0.05	5150	24.2	2	28.4	105	1435	23
2011/4/21 20:00								
2011/4/21 22:00								
2011/4/22 0:00								
2011/4/22 2:00								
2011/4/22 4:00								
2011/4/22 6:00								
2011/4/22 8:00								
2011/4/22 10:00								
2011/4/22 12:00								
2011/4/22 14:00								
2011/4/22 16:00								
2011/4/22 18:00								
2011/4/22 20:00								
2011/4/22 22:00								
2011/4/23 0:00								

NO.1420

東京電力(株)原子力部 記録簿

2011年4月21日 10時27分

# 2F-2号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa (gage)]	炉水位 [mm] 停止時	炉水温度[°C] 給水/スル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
			24.6	4.6	30.1	104	1200	24
2011/4/20 0:00	0.03	6100	24.6	4.5	30.0	105	1200	24
2011/4/20 2:00	0.04	6100	24.6	4.5	30.0	105	1200	24
2011/4/20 4:00	0.04	6100	24.5	4.4	30.0	105	1200	24
2011/4/20 6:00	0.04	6100	24.3	3.7	30.0	104	1200	23
2011/4/20 8:00	0.03	6100	24.3	3.6	30.0	104	1200	24
2011/4/20 10:00	0.04	6100	24.2	3.4	30.0	104	1200	23
2011/4/20 12:00	0.04	6100	24.2	3.2	29.7	104	1200	23
2011/4/20 14:00	0.04	6100	24.2	3.1	29.9	104	1200	23
2011/4/20 16:00	0.04	6050	24.3	2.9	29.9	104	1200	24
2011/4/20 18:00	0.04	6100	24.3	2.7	29.9	104	1200	24
2011/4/20 20:00	0.04	6100	24.4	2.6	29.9	104	1200	24
2011/4/20 22:00	0.04	6100	24.4	2.5	29.9	104	1200	24
2011/4/21 0:00	0.04	6100	24.4	2.5	29.9	104	1200	24
2011/4/21 2:00	0.04	6100	24.4	2.4	29.9	104	1200	24
2011/4/21 4:00	0.04	6100	24.5	2.4	29.9	104	1200	24
2011/4/21 6:00	0.04	6100	24.5	2.4	29.9	104	1200	24
2011/4/21 8:00	0.03	6100	24.5	2.4	29.9	104	1200	24
2011/4/21 10:00	0.03	6100	24.5	2.4	29.7	104	1200	24
2011/4/21 12:00	0.03	6100	24.6	2.5	29.6	104	1200	24
2011/4/21 14:00	0.04	6100	24.6	2.5	29.6	104	1200	24
2011/4/21 16:00	0.04	6100	24.6	2.4	29.6	104	1200	24
2011/4/21 18:00	0.04	6100	24.6	2.4	29.6	104	1200	24
2011/4/21 20:00								
2011/4/21 22:00								
2011/4/22 0:00								
2011/4/22 2:00								
2011/4/22 4:00								
2011/4/22 6:00								
2011/4/22 8:00								
2011/4/22 10:00								
2011/4/22 12:00								
2011/4/22 14:00								
2011/4/22 16:00								
2011/4/22 18:00								
2011/4/22 20:00								
2011/4/22 22:00								
2011/4/23 0:00								

NO. 1470

水素部/機/原/機/機

2011年 4月 10日 10時 27分

# 2F-3号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa (gage)]	炉水位 [mm] アップセット	炉水温度[°C] 給水/スル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/4/20 0:00	0.00	3597	33.2	11	34.3	110	2100	26
2011/4/20 2:00	0.00	3597	33.1	11	34.3	110	2100	26
2011/4/20 4:00	0.00	3597	33.0	11	34.0	111	2100	26
2011/4/20 6:00	0.00	3596	32.9	10	34.0	110	2100	26
2011/4/20 8:00	0.00	3596	32.8	10	34.0	110	2100	26
2011/4/20 10:00	0.00	3596	32.7	10	34.0	111	2100	26
2011/4/20 12:00	0.00	3596	32.7	10	33.9	111	2100	26
2011/4/20 14:00	0.00	3596	32.7	10	33.9	111	2100	26
2011/4/20 16:00	0.00	3594	32.7	9	33.9	110	2100	26
2011/4/20 18:00	0.00	3593	32.8	9	33.9	110	2100	26
2011/4/20 20:00	0.00	3593	32.8	9	33.9	110	2100	26
2011/4/20 22:00	0.00	3593	32.8	9	33.9	110	2100	26
2011/4/21 0:00	0.00	3593	32.8	9	33.8	110	2100	26
2011/4/21 2:00	0.00	3593	32.8	9	33.9	110	2100	26
2011/4/21 4:00	0.00	3593	32.8	9	33.8	110	2100	26
2011/4/21 6:00	0.00	3593	32.9	9	33.8	110	2100	26
2011/4/21 8:00	0.00	3593	32.8	9	33.7	110	2100	26
2011/4/21 10:00	0.00	3593	32.8	9	33.7	110	2100	26
2011/4/21 12:00	0.00	3593	32.8	9	33.8	110	2100	26
2011/4/21 14:00	0.00	3593	33.0	9	33.7	110	2100	26
2011/4/21 16:00	0.00	3593	33.1	9	33.7	110	2100	26
2011/4/21 18:00	0.00	3593	33.2	9	33.7	110	2100	26
2011/4/21 20:00								
2011/4/21 22:00								
2011/4/22 0:00								
2011/4/22 2:00								
2011/4/22 4:00								
2011/4/22 6:00								
2011/4/22 8:00								
2011/4/22 10:00								
2011/4/22 12:00								
2011/4/22 14:00								
2011/4/22 16:00								
2011/4/22 18:00								
2011/4/22 20:00								
2011/4/22 22:00								
2011/4/23 0:00								

# 2F-4号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa (gage)]	炉水位 [mm] アツプセット	炉水温度[°C] 給水/スル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/4/20 0:00	0.07	4589	28.8	7	33.3	107	2050	29
2011/4/20 2:00	0.07	4589	28.8	7	33.3	107	2000	29
2011/4/20 4:00	0.07	4589	28.8	7	33.3	107	2000	29
2011/4/20 6:00	0.07	4589	28.7	7	32.9	107	2000	29
2011/4/20 8:00	0.07	4589	28.6	6	32.8	107	2050	29
2011/4/20 10:00	0.07	4589	28.5	6	33.0	107	2050	29
2011/4/20 12:00	0.07	4589	28.5	6	33.1	106	2050	29
2011/4/20 14:00	0.07	4589	28.5	6	33.1	106	2050	29
2011/4/20 16:00	0.07	4589	28.5	6	33.2	107	2050	29
2011/4/20 18:00	0.07	4589	28.4	5	32.5	107	2000	29
2011/4/20 20:00	0.07	4589	28.4	5	32.5	107	2000	29
2011/4/20 22:00	0.07	4589	28.4	5	32.9	107	2050	29
2011/4/21 0:00	0.07	4589	28.3	5	32.4	107	2050	29
2011/4/21 2:00	0.07	4589	28.3	5	32.4	107	2050	29
2011/4/21 4:00	0.07	4589	28.2	5	32.5	107	2050	29
2011/4/21 6:00	0.07	4589	28.2	5	32.1	107	2050	29
2011/4/21 8:00	0.07	4589	28.2	5	32.3	107	2050	29
2011/4/21 10:00	0.07	4598	28.2	5	32.6	107	2050	29
2011/4/21 12:00	0.07	4598	28.2	5	32.9	107	2050	29
2011/4/21 14:00	0.07	4589	28.1	5	32.7	107	2050	29
2011/4/21 16:00	0.07	4589	28.1	5	32.3	107	2050	29
2011/4/21 18:00	0.07	4589	28.1	5	32.5	107	2000	29
2011/4/21 20:00								
2011/4/21 22:00								
2011/4/22 0:00								
2011/4/22 2:00								
2011/4/22 4:00								
2011/4/22 6:00								
2011/4/22 8:00								
2011/4/22 10:00								
2011/4/22 12:00								
2011/4/22 14:00								
2011/4/22 16:00								
2011/4/22 18:00								
2011/4/22 20:00								
2011/4/22 22:00								
2011/4/23 0:00								

NO. 1720

水取部/炉内/水位 記録

2011年 4月21日 10時27分

# 2F-1号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa (gage)]	炉水位 [mm] 停止時	炉水温度[°C] 給水ノズル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/4/20 0:00	0.05	5100	24.7	5	28.8	105	1435	24
2011/4/20 2:00	0.05	5150	24.7	5	29.0	105	1435	24
2011/4/20 4:00	0.05	5150	24.7	4	28.9	105	1435	24
2011/4/20 6:00	0.05	5150	24.6	4	28.8	105	1434	24
2011/4/20 8:00	0.05	5150	24.5	3	28.8	105	1436	24
2011/4/20 10:00	0.05	5150	24.5	3	28.8	105	1436	24
2011/4/20 12:00	0.05	5150	24.4	3	28.7	105	1433	23
2011/4/20 14:00	0.05	5150	24.4	3	28.8	105	1435	23
2011/4/20 16:00	0.05	5150	24.3	3	28.7	105	1436	23
2011/4/20 18:00	0.05	5150	24.3	2	28.7	105	1435	23
2011/4/20 20:00	0.05	5150	24.3	2	28.6	105	1434	23
2011/4/20 22:00	0.05	5150	24.3	2	28.7	105	1437	23
2011/4/21 0:00	0.05	5150	24.3	2	28.5	105	1437	23
2011/4/21 2:00	0.05	5150	24.3	2	28.6	105	1437	23
2011/4/21 4:00	0.05	5150	24.2	2	28.6	105	1437	23
2011/4/21 6:00	0.05	5150	24.2	2	28.5	105	1437	23
2011/4/21 8:00	0.05	5150	24.2	2	28.5	105	1437	23
2011/4/21 10:00	0.05	5150	24.2	2	28.5	105	1436	23
2011/4/21 12:00	0.05	5150	24.2	2	28.4	105	1437	23
2011/4/21 14:00	0.05	5150	24.2	2	28.5	105	1435	23
2011/4/21 16:00	0.05	5150	24.2	2	28.6	105	1435	23
2011/4/21 18:00	0.05	5150	24.2	2	28.4	105	1435	23
2011/4/21 20:00	0.05	5150	24.2	2	28.5	105	1437	23
2011/4/21 22:00	0.05	5150	24.2	2	28.4	105	1434	23
2011/4/22 0:00								
2011/4/22 2:00								
2011/4/22 4:00								
2011/4/22 6:00								
2011/4/22 8:00								
2011/4/22 10:00								
2011/4/22 12:00								
2011/4/22 14:00								
2011/4/22 16:00								
2011/4/22 18:00								
2011/4/22 20:00								
2011/4/22 22:00								
2011/4/23 0:00								

# 2F-2号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa (gage)]	炉水位 [mm] 停止時	炉水温度[°C] 給水/スル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/4/20 0:00	0.03	6100	24.8	4.6	30.1	104	1200	24
2011/4/20 2:00	0.04	6100	24.6	4.5	30.0	105	1200	24
2011/4/20 4:00	0.04	6100	24.6	4.5	30.0	105	1200	24
2011/4/20 6:00	0.04	6100	24.5	4.4	30.0	105	1200	24
2011/4/20 8:00	0.03	6100	24.3	3.7	30.0	104	1200	23
2011/4/20 10:00	0.04	6100	24.3	3.6	30.0	104	1200	24
2011/4/20 12:00	0.04	6100	24.2	3.4	30.0	104	1200	24
2011/4/20 14:00	0.04	6100	24.2	3.2	29.7	104	1200	23
2011/4/20 16:00	0.04	6050	24.2	3.1	29.9	104	1200	23
2011/4/20 18:00	0.04	6100	24.3	2.9	29.9	104	1200	23
2011/4/20 20:00	0.04	6100	24.3	2.7	29.9	104	1200	24
2011/4/20 22:00	0.04	6100	24.4	2.6	29.9	104	1200	24
2011/4/21 0:00	0.04	6100	24.4	2.5	29.9	104	1200	24
2011/4/21 2:00	0.04	6100	24.4	2.5	29.9	104	1200	24
2011/4/21 4:00	0.04	6100	24.4	2.4	29.9	104	1200	24
2011/4/21 6:00	0.04	6100	24.5	2.4	29.9	104	1200	24
2011/4/21 8:00	0.03	6100	24.5	2.4	29.9	104	1200	24
2011/4/21 10:00	0.03	6100	24.5	2.4	29.9	104	1200	24
2011/4/21 12:00	0.03	6100	24.5	2.4	29.7	104	1200	24
2011/4/21 14:00	0.04	6100	24.6	2.5	29.6	104	1200	24
2011/4/21 16:00	0.04	6100	24.6	2.5	29.6	104	1200	24
2011/4/21 18:00	0.04	6100	24.6	2.4	29.6	104	1200	24
2011/4/21 20:00	0.03	6100	24.6	2.4	29.6	104	1200	24
<b>2011/4/21 22:00</b>	<b>0.03</b>	<b>6100</b>	<b>24.6</b>	<b>2.4</b>	<b>29.6</b>	<b>104</b>	<b>1200</b>	<b>24</b>
2011/4/22 0:00								
2011/4/22 2:00								
2011/4/22 4:00								
2011/4/22 6:00								
2011/4/22 8:00								
2011/4/22 10:00								
2011/4/22 12:00								
2011/4/22 14:00								
2011/4/22 16:00								
2011/4/22 18:00								
2011/4/22 20:00								
2011/4/22 22:00								
2011/4/23 0:00								

# 2F-3号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa (gage)]	炉水位 [mm] アツブセット	炉水温度[°C] 給水/スル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/G圧力 [kPa(abs)]	S/G水位 [mm]	S/G温度 [°C]
2011/4/20 0:00	0.00	3597	33.2	11	34.3	110	2100	26
2011/4/20 2:00	0.00	3597	33.1	11	34.3	110	2100	26
2011/4/20 4:00	0.00	3597	33.0	11	34.0	111	2100	26
2011/4/20 6:00	0.00	3596	32.9	10	34.0	110	2100	26
2011/4/20 8:00	0.00	3596	32.8	10	34.0	110	2100	26
2011/4/20 10:00	0.00	3596	32.7	10	34.0	111	2100	26
2011/4/20 12:00	0.00	3596	32.7	10	33.9	111	2100	26
2011/4/20 14:00	0.00	3596	32.7	10	33.9	111	2100	26
2011/4/20 16:00	0.00	3594	32.7	9	33.9	110	2100	26
2011/4/20 18:00	0.00	3593	32.8	9	33.9	110	2100	26
2011/4/20 20:00	0.00	3593	32.8	9	33.9	110	2100	26
2011/4/20 22:00	0.00	3593	32.8	9	33.9	110	2100	26
2011/4/21 0:00	0.00	3593	32.8	9	33.9	110	2100	26
2011/4/21 2:00	0.00	3593	32.8	9	33.8	110	2100	26
2011/4/21 4:00	0.00	3593	32.8	9	33.9	110	2100	26
2011/4/21 6:00	0.00	3593	32.9	9	33.8	110	2100	26
2011/4/21 8:00	0.00	3593	32.8	9	33.7	110	2100	26
2011/4/21 10:00	0.00	3593	32.8	9	33.7	110	2100	26
2011/4/21 12:00	0.00	3593	32.8	9	33.8	110	2100	26
2011/4/21 14:00	0.00	3593	33.0	9	33.7	110	2100	26
2011/4/21 16:00	0.00	3593	33.1	9	33.7	110	2100	26
2011/4/21 18:00	0.00	3593	33.2	9	33.7	110	2100	26
2011/4/21 20:00	0.00	3593	33.3	9	33.8	110	2100	26
2011/4/21 22:00	0.00	3594	33.3	9	33.7	111	2100	26
2011/4/22 0:00								
2011/4/22 2:00								
2011/4/22 4:00								
2011/4/22 6:00								
2011/4/22 8:00								
2011/4/22 10:00								
2011/4/22 12:00								
2011/4/22 14:00								
2011/4/22 16:00								
2011/4/22 18:00								
2011/4/22 20:00								
2011/4/22 22:00								
2011/4/23 0:00								

## 2F-4号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa (gage)]	炉水位 [mm] アツプセット	炉水温度[°C] 給水/スル温度	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/4/20 0:00	0.07	4589	28.8	7	33.3	107	2050	29
2011/4/20 2:00	0.07	4589	28.8	7	33.3	107	2000	29
2011/4/20 4:00	0.07	4589	28.8	7	33.3	107	2000	29
2011/4/20 6:00	0.07	4589	28.7	7	32.9	107	2000	29
2011/4/20 8:00	0.07	4589	28.6	6	32.8	107	2050	29
2011/4/20 10:00	0.07	4589	28.5	6	33.0	107	2050	29
2011/4/20 12:00	0.07	4589	28.5	6	33.1	106	2050	29
2011/4/20 14:00	0.07	4589	28.5	6	33.1	106	2050	29
2011/4/20 16:00	0.07	4589	28.5	6	33.2	107	2050	29
2011/4/20 18:00	0.07	4589	28.4	5	32.5	107	2000	29
2011/4/20 20:00	0.07	4589	28.4	5	32.5	107	2000	29
2011/4/20 22:00	0.07	4589	28.4	5	32.9	107	2050	29
2011/4/21 0:00	0.07	4589	28.3	5	32.4	107	2050	29
2011/4/21 2:00	0.07	4589	28.3	5	32.4	107	2050	29
2011/4/21 4:00	0.07	4589	28.2	5	32.5	107	2050	29
2011/4/21 6:00	0.07	4589	28.2	5	32.1	107	2050	29
2011/4/21 8:00	0.07	4589	28.2	5	32.3	107	2050	29
2011/4/21 10:00	0.07	4598	28.2	5	32.6	107	2050	29
2011/4/21 12:00	0.07	4598	28.1	5	32.9	107	2050	29
2011/4/21 14:00	0.07	4589	28.1	5	32.7	107	2050	29
2011/4/21 16:00	0.07	4589	28.1	5	32.3	107	2050	29
2011/4/21 18:00	0.07	4589	28.1	5	32.5	107	2000	29
2011/4/21 20:00	0.07	4589	28.2	5	32.9	107	2000	29
<b>2011/4/21 22:00</b>	<b>0.07</b>	<b>4589</b>	<b>28.1</b>	<b>5</b>	<b>32.4</b>	<b>106</b>	<b>2000</b>	<b>29</b>
2011/4/22 0:00								
2011/4/22 2:00								
2011/4/22 4:00								
2011/4/22 6:00								
2011/4/22 8:00								
2011/4/22 10:00								
2011/4/22 12:00								
2011/4/22 14:00								
2011/4/22 16:00								
2011/4/22 18:00								
2011/4/22 20:00								
2011/4/22 22:00								
2011/4/23 0:00								

2011年4月20日 22時00分 2F-4号機 炉内監視記録