




2F-1号機




2F-2号機



2F-3号機



2F-4号機







2F-2号機


※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa (gage)]	炉水位 [mm] 停止時	炉水温度[°C]	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/6/13 0:00	0.04	5650	24.4	7	26.0	107	1200	24
2011/6/13 2:00	0.04	5650	24.4	7	26.0	107	1200	24
2011/6/13 4:00	0.04	5650	24.5	7	26.0	107	1200	24
2011/6/13 6:00	0.03	5650	24.5	7	26.2	107	1200	24
2011/6/13 8:00	0.04	5650	24.6	7	26.2	107	1200	24
2011/6/13 10:00	0.04	5650	24.6	7	26.2	107	1200	24
2011/6/13 12:00	0.04	5650	24.6	7	26.2	107	1200	24
2011/6/13 14:00	0.04	5650	24.7	7	26.2	107	1200	24
2011/6/13 16:00	0.04	5650	24.7	7	26.2	107	1200	24
2011/6/13 18:00	0.03	5650	24.8	7	26.2	107	1200	24
2011/6/13 20:00	0.03	5650	24.9	7	26.2	107	1200	24
2011/6/13 22:00	0.04	5650	24.9	7	26.0	107	1200	25
2011/6/14 0:00	0.04	5650	25.0	7	26.0	107	1200	25
2011/6/14 2:00	0.04	5650	25.1	7	26.2	107	1200	25
2011/6/14 4:00	0.03	5650	25.1	7	26.0	107	1200	25
2011/6/14 6:00	0.04	5650	25.1	7	26.0	107	1200	25
2011/6/14 8:00	0.03	5650	25.2	7	26.2	107	1200	25
2011/6/14 10:00	0.04	5650	25.3	7	26.2	107	1200	25
2011/6/14 12:00	0.04	5650	25.3	7	26.2	107	1200	25
2011/6/14 14:00	0.04	5650	25.4	7	26.2	107	1200	25
2011/6/14 16:00	0.04	5650	25.5	7	26.2	107	1200	25
2011/6/14 18:00	0.04	5650	25.5	7	26.2	107	1200	25
2011/6/14 20:00	0.04	5650	25.6	7	26.2	107	1200	25
2011/6/14 22:00	0.04	5650	25.7	7	26.2	107	1200	25
2011/6/15 0:00	0.03	5650	25.7	7	26.2	107	1200	25
2011/6/15 2:00	0.04	5650	25.8	6	26.2	107	1200	26
2011/6/15 4:00	0.03	5650	25.7	6	26.2	107	1200	26
2011/6/15 6:00	0.04	5650	25.7	6	26.2	107	1200	26
2011/6/15 8:00								
2011/6/15 10:00								
2011/6/15 12:00								
2011/6/15 14:00								
2011/6/15 16:00								
2011/6/15 18:00								
2011/6/15 20:00								
2011/6/15 22:00								
2011/6/16 0:00								


2F-1号機




2F-2号機



2F-3号機



2F-4号機



2F-1号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa (gage)]	炉水位 [mm] 停止時	炉水温度[°C]	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/6/13 0:00	0.05	5700	24.0	4	25.8	105	1960	24
2011/6/13 2:00	0.05	5700	24.0	4	25.9	105	1960	24
2011/6/13 4:00	0.05	5700	24.0	4	26.0	105	1959	24
2011/6/13 6:00	0.05	5700	24.0	4	26.0	105	1959	24
2011/6/13 8:00	0.05	5700	24.1	4	26.0	105	1960	24
2011/6/13 10:00	0.05	5700	24.1	4	25.8	105	1959	24
2011/6/13 12:00	0.05	5700	24.2	4	25.8	105	1959	24
2011/6/13 14:00	0.05	5700	24.2	4	25.7	105	1960	24
2011/6/13 16:00	0.05	5700	24.2	4	25.8	105	1960	24
2011/6/13 18:00	0.05	5700	24.3	4	25.8	105	1960	24
2011/6/13 20:00	0.05	5700	24.3	4	25.8	105	1960	24
2011/6/13 22:00	0.05	5700	24.4	4	25.9	105	1960	24
2011/6/14 0:00	0.05	5700	24.4	4	26.0	105	1961	24
2011/6/14 2:00	0.05	5700	24.3	4	25.9	105	1961	24
2011/6/14 4:00	0.05	5700	24.3	4	26.0	105	1961	24
2011/6/14 6:00	0.05	5700	24.2	4	26.0	105	1961	24
2011/6/14 8:00	0.05	5700	24.2	4	26.0	105	1961	24
2011/6/14 10:00	0.05	5700	24.2	4	26.0	105	1961	24
2011/6/14 12:00	0.05	5700	24.3	4	26.0	105	1961	24
2011/6/14 14:00	0.05	5700	24.3	4	25.9	105	1961	24
2011/6/14 16:00	0.05	5700	24.3	4	25.9	105	1961	24
2011/6/14 18:00	0.05	5700	24.3	4	25.9	105	1962	24
2011/6/14 20:00	0.05	5700	24.3	4	26.0	105	1961	24
2011/6/14 22:00	0.05	5700	24.4	4	26.0	105	1962	25
2011/6/15 0:00	0.05	5700	24.4	4	26.0	105	1962	25
2011/6/15 2:00	0.05	5700	24.4	4	26.0	105	1962	25
2011/6/15 4:00	0.05	5700	24.4	4	26.0	105	1962	25
2011/6/15 6:00	0.05	5700	24.4	4	26.1	105	1962	25
2011/6/15 8:00	0.05	5700	24.4	3	26.0	105	1963	25
2011/6/15 10:00	0.05	5700	24.4	3	26.0	105	1962	24
2011/6/15 12:00	0.05	5700	24.4	3	26.2	105	1962	25
2011/6/15 14:00								
2011/6/15 16:00								
2011/6/15 18:00								
2011/6/15 20:00								
2011/6/15 22:00								
2011/6/16 0:00								

2F-4号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa (gage)]	炉水位 [mm] 停止時	炉水温度[°C]	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/6/13 0:00	0.07	3950	30.3	6	29.1	106	2000	28
2011/6/13 2:00	0.07	3950	29.9	7	29.1	106	2000	28
2011/6/13 4:00	0.07	3950	29.7	7	29.1	106	2000	28
2011/6/13 6:00	0.07	3950	29.7	7	29.1	106	2050	28
2011/6/13 8:00	0.07	4000	29.6	7	29.1	106	2050	28
2011/6/13 10:00	0.07	4000	29.6	7	29.1	106	2000	28
2011/6/13 12:00	0.07	4000	29.7	7	29.1	106	2000	28
2011/6/13 14:00	0.07	4000	29.6	7	29.1	106	2000	28
2011/6/13 16:00	0.07	4000	29.6	7	29.1	106	2000	28
2011/6/13 18:00	0.07	4000	29.8	7	29.1	106	2000	28
2011/6/13 20:00	0.07	4050	29.9	7	29.1	106	2000	28
2011/6/13 22:00	0.07	4050	30.0	6	29.1	106	2000	28
2011/6/14 0:00	0.07	3950	30.1	6	29.1	106	2000	28
2011/6/14 2:00	0.07	3950	30.2	6	29.1	106	2000	28
2011/6/14 4:00	0.07	4000	30.3	6	29.1	106	2000	28
2011/6/14 6:00	0.07	4000	30.4	6	29.1	106	2000	28
2011/6/14 8:00	0.07	4000	30.4	6	29.2	106	2000	28
2011/6/14 10:00	0.07	4000	30.5	6	29.1	106	2000	28
2011/6/14 12:00	0.07	4000	30.5	6	29.3	106	2000	28
2011/6/14 14:00	0.07	4000	30.6	6	29.3	106	2000	28
2011/6/14 16:00	0.07	4000	30.7	6	29.3	106	2000	28
2011/6/14 18:00	0.07	4050	30.6	6	29.2	106	2000	28
2011/6/14 20:00	0.07	4050	30.4	6	29.3	106	2000	28
2011/6/14 22:00	0.07	4100	30.3	6	29.3	106	2000	28
2011/6/15 0:00	0.07	4000	30.3	6	29.3	106	2000	28
2011/6/15 2:00	0.07	4000	30.2	6	29.3	106	2000	28
2011/6/15 4:00	0.07	4000	30.1	6	29.3	106	2000	28
2011/6/15 6:00	0.07	4000	29.9	6	29.3	106	2000	28
2011/6/15 8:00	0.07	4000	29.9	6	29.3	106	2000	28
2011/6/15 10:00	0.07	4000	30.0	6	29.2	106	2000	28
2011/6/15 12:00	0.07	4000	30.1	6	29.3	107	2000	28
2011/6/15 14:00								
2011/6/15 16:00								
2011/6/15 18:00								
2011/6/15 20:00								
2011/6/15 22:00								
2011/6/16 0:00								