




2F-1号機




2F-2号機



2F-3号機



2F-4号機



2F-1号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa (gage)]	炉水位 [mm] 停止時	炉水温度[°C]	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/8/3 0:00	0.04	4050	27.2	5	28.4	106	2210	27
2011/8/3 2:00	0.04	4100	26.9	5	28.4	106	2210	27
2011/8/3 4:00	0.04	4100	26.4	5	28.4	106	2210	27
2011/8/3 6:00	0.04	4100	26.1	5	28.4	106	2210	27
2011/8/3 8:00	0.04	4150	26.1	5	28.4	106	2210	27
2011/8/3 10:00	0.04	4150	26.3	5	28.4	106	2210	27
2011/8/3 12:00	0.05	4200	26.5	5	28.5	106	2210	27
2011/8/3 14:00	0.04	4050	26.7	5	28.4	106	2210	27
2011/8/3 16:00	0.04	4050	26.7	5	28.4	106	2211	27
2011/8/3 18:00	0.04	4050	26.7	5	28.4	106	2210	27
2011/8/3 20:00	0.04	4050	26.6	5	28.5	106	2211	27
2011/8/3 22:00	0.04	4100	26.4	5	28.3	106	2211	27
2011/8/4 0:00	0.04	4100	26.4	5	28.5	106	2211	27
2011/8/4 2:00	0.04	4150	26.4	5	28.5	106	2211	27
2011/8/4 4:00	0.04	4150	26.4	5	28.5	106	2211	27
2011/8/4 6:00	0.04	4000	26.5	5	28.5	106	2211	27
2011/8/4 8:00	0.04	4000	26.5	5	28.4	106	2211	27
2011/8/4 10:00	0.04	4050	26.4	5	28.4	106	2211	27
2011/8/4 12:00	0.04	4050	26.2	5	28.5	106	2211	27
2011/8/4 14:00	0.04	4100	26.1	5	28.4	106	2211	27
2011/8/4 16:00	0.04	4100	26.0	5	28.4	106	2211	27
2011/8/4 18:00	0.04	4100	25.9	5	28.5	106	2212	27
2011/8/4 20:00	0.04	4150	26.0	5	28.4	106	2212	27
2011/8/4 22:00	0.04	4200	25.9	5	28.4	106	2212	27
2011/8/5 0:00	0.04	4000	25.8	5	28.3	106	2212	27
2011/8/5 2:00	0.04	4000	25.8	5	28.4	106	2212	27
2011/8/5 4:00	0.04	4000	25.8	5	28.4	106	2212	27
2011/8/5 6:00	0.04	4000	25.6	5	28.4	106	2212	27
2011/8/5 8:00								
2011/8/5 10:00								
2011/8/5 12:00								
2011/8/5 14:00								
2011/8/5 16:00								
2011/8/5 18:00								
2011/8/5 20:00								
2011/8/5 22:00								

2F-3号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]


時間	炉圧 [MPa (gage)]	炉水位 [mm] 停止時	炉水温度[°C]	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/8/3 0:00	0.02	4100	31.3	9	29.6	110	2100	28
2011/8/3 2:00	0.02	4100	31.0	9	29.6	110	2100	28
2011/8/3 4:00	0.02	4100	30.5	9	29.6	110	2100	28
2011/8/3 6:00	0.02	4150	30.1	9	29.6	110	2100	28
2011/8/3 8:00	0.02	4150	30.0	9	29.6	110	2100	28
2011/8/3 10:00	0.02	4150	30.1	9	29.6	110	2100	28
2011/8/3 12:00	0.02	4150	30.4	9	29.6	110	2100	28
2011/8/3 14:00	0.02	4150	30.5	9	29.6	110	2100	28
2011/8/3 16:00	0.02	4150	30.6	9	29.5	110	2100	28
2011/8/3 18:00	0.02	4150	30.6	9	29.6	110	2100	28
2011/8/3 20:00	0.02	4150	30.6	9	29.6	110	2100	28
2011/8/3 22:00	0.02	4150	30.5	9	29.6	110	2100	28
2011/8/4 0:00	0.02	4200	30.4	9	29.6	110	2100	28
2011/8/4 2:00	0.02	4000	30.3	9	29.5	110	2100	28
2011/8/4 4:00	0.02	4000	30.3	9	29.6	110	2100	28
2011/8/4 6:00	0.02	4000	30.4	9	29.5	110	2100	28
2011/8/4 8:00	0.02	4000	30.5	9	29.5	110	2100	28
2011/8/4 10:00	0.02	4000	30.4	9	29.5	110	2100	28
2011/8/4 12:00	0.02	4000	30.2	9	29.5	110	2100	28
2011/8/4 14:00	0.02	4000	30.0	9	29.5	110	2100	28
2011/8/4 16:00	0.02	4000	29.8	9	29.5	110	2100	28
2011/8/4 18:00	0.02	4000	29.7	9	29.5	110	2100	28
2011/8/4 20:00	0.02	4000	29.7	9	29.5	110	2100	28
2011/8/4 22:00	0.02	4000	29.8	9	29.5	110	2100	28
2011/8/5 0:00	0.02	4050	29.8	9	29.5	110	2100	28
2011/8/5 2:00	0.02	4050	29.7	9	29.5	110	2100	28
2011/8/5 4:00	0.02	4050	29.6	9	29.5	110	2100	28
2011/8/5 6:00	0.02	4050	29.5	9	29.5	110	2100	28
2011/8/5 8:00								
2011/8/5 10:00								
2011/8/5 12:00								
2011/8/5 14:00								
2011/8/5 16:00								
2011/8/5 18:00								
2011/8/5 20:00								
2011/8/5 22:00								

2F-4号機


※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa (gage)]	炉水位 [mm] 停止時	炉水温度[°C]	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/8/3 0:00	0.07	4150	29.2	6	29.3	107	2050	28
2011/8/3 2:00	0.07	4000	29.1	6	29.3	107	2050	28
2011/8/3 4:00	0.07	4000	28.6	6	29.4	107	2050	28
2011/8/3 6:00	0.07	4000	28.2	6	29.3	107	2050	28
2011/8/3 8:00	0.07	4000	28.1	6	29.3	107	2050	28
2011/8/3 10:00	0.07	4000	28.1	6	29.2	107	2050	28
2011/8/3 12:00	0.07	4000	28.3	6	29.3	107	2050	28
2011/8/3 14:00	0.07	4000	28.5	6	29.4	107	2050	28
2011/8/3 16:00	0.07	4050	28.6	6	29.4	107	2050	28
2011/8/3 18:00	0.07	4050	28.6	6	29.3	107	2050	28
2011/8/3 20:00	0.07	4050	28.5	6	29.4	107	2050	28
2011/8/3 22:00	0.07	4050	28.5	6	29.4	107	2050	28
2011/8/4 0:00	0.07	4100	29.7	6	29.2	107	2050	28
2011/8/4 2:00	0.07	4150	29.6	6	29.4	107	2050	28
2011/8/4 4:00	0.08	4150	29.7	6	29.4	107	2050	28
2011/8/4 6:00	0.08	4050	29.7	6	29.4	107	2050	28
2011/8/4 8:00	0.07	4050	29.8	6	29.5	107	2050	28
2011/8/4 10:00	0.07	4050	29.8	6	29.5	107	2050	28
2011/8/4 12:00	0.07	4050	29.7	6	29.5	107	2050	28
2011/8/4 14:00	0.07	4050	29.6	6	29.5	107	2050	28
2011/8/4 16:00	0.07	4050	29.5	6	29.4	107	2050	28
2011/8/4 18:00	0.08	4100	29.3	6	29.4	107	2050	28
2011/8/4 20:00	0.08	4100	29.3	6	29.5	107	2050	28
2011/8/4 22:00	0.08	4100	29.3	6	29.4	107	2050	28
2011/8/5 0:00	0.07	4000	29.3	6	29.4	107	2050	28
2011/8/5 2:00	0.07	4000	29.2	6	29.4	107	2050	28
2011/8/5 4:00	0.07	4000	29.2	6	29.4	107	2050	28
2011/8/5 6:00	0.07	4000	29.1	6	29.4	107	2050	28
2011/8/5 8:00								
2011/8/5 10:00								
2011/8/5 12:00								
2011/8/5 14:00								
2011/8/5 16:00								
2011/8/5 18:00								
2011/8/5 20:00								
2011/8/5 22:00								


2F-1号機







2F-2号機



2F-3号機



2F-4号機



2F-1号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa (gage)]	炉水位 [mm] 停止時	炉水温度[°C]	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/8/3 0:00	0.04	4050	27.2	5	28.4	106	2210	27
2011/8/3 2:00	0.04	4100	26.9	5	28.4	106	2210	27
2011/8/3 4:00	0.04	4100	26.4	5	28.4	106	2210	27
2011/8/3 6:00	0.04	4100	26.1	5	28.4	106	2210	27
2011/8/3 8:00	0.04	4150	26.1	5	28.4	106	2210	27
2011/8/3 10:00	0.04	4150	26.3	5	28.4	106	2210	27
2011/8/3 12:00	0.05	4200	26.5	5	28.5	106	2210	27
2011/8/3 14:00	0.04	4050	26.7	5	28.4	106	2210	27
2011/8/3 16:00	0.04	4050	26.7	5	28.4	106	2211	27
2011/8/3 18:00	0.04	4050	26.7	5	28.4	106	2210	27
2011/8/3 20:00	0.04	4050	26.6	5	28.5	106	2211	27
2011/8/3 22:00	0.04	4100	26.4	5	28.3	106	2211	27
2011/8/4 0:00	0.04	4100	26.4	5	28.5	106	2211	27
2011/8/4 2:00	0.04	4150	26.4	5	28.5	106	2211	27
2011/8/4 4:00	0.04	4150	26.4	5	28.5	106	2211	27
2011/8/4 6:00	0.04	4000	26.5	5	28.5	106	2211	27
2011/8/4 8:00	0.04	4000	26.5	5	28.4	106	2211	27
2011/8/4 10:00	0.04	4050	26.4	5	28.4	106	2211	27
2011/8/4 12:00	0.04	4050	26.2	5	28.5	106	2211	27
2011/8/4 14:00	0.04	4100	26.1	5	28.4	106	2211	27
2011/8/4 16:00	0.04	4100	26.0	5	28.4	106	2211	27
2011/8/4 18:00	0.04	4100	25.9	5	28.5	106	2212	27
2011/8/4 20:00	0.04	4150	26.0	5	28.4	106	2212	27
2011/8/4 22:00	0.04	4200	25.9	5	28.4	106	2212	27
2011/8/5 0:00	0.04	4000	25.8	5	28.3	106	2212	27
2011/8/5 2:00	0.04	4000	25.8	5	28.4	106	2212	27
2011/8/5 4:00	0.04	4000	25.8	5	28.4	106	2212	27
2011/8/5 6:00	0.04	4000	25.6	5	28.4	106	2212	27
2011/8/5 8:00	0.04	4050	25.5	5	28.3	106	2212	27
2011/8/5 10:00	0.04	4050	25.5	5	28.3	106	2212	27
2011/8/5 12:00	0.04	4100	25.3	5	28.5	106	2212	27
2011/8/5 14:00								
2011/8/5 16:00								
2011/8/5 18:00								
2011/8/5 20:00								
2011/8/5 22:00								

2F-2号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa (gage)]	炉水位 [mm] 停止時	炉水温度[°C]	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/8/3 0:00	-0.01	4050	27.6	4	28.0	105	1100	28
2011/8/3 2:00	-0.01	4050	27.1	4	28.0	105	1100	28
2011/8/3 4:00	-0.01	4050	26.6	4	28.0	105	1100	28
2011/8/3 6:00	-0.01	4050	26.3	4	28.0	105	1100	28
2011/8/3 8:00	-0.01	4050	26.4	4	28.0	105	1100	28
2011/8/3 10:00	-0.01	4050	26.6	4	28.0	105	1100	28
2011/8/3 12:00	-0.01	4050	26.8	4	28.0	105	1100	28
2011/8/3 14:00	0.00	4050	26.9	4	28.0	105	1100	28
2011/8/3 16:00	0.00	4050	26.9	4	28.0	105	1100	28
2011/8/3 18:00	0.00	4050	26.8	4	28.0	105	1100	28
2011/8/3 20:00	0.00	4050	26.7	4	28.0	105	1100	28
2011/8/3 22:00	0.00	4050	26.6	4	28.0	105	1100	28
2011/8/4 0:00	0.00	4050	26.5	4	28.0	105	1100	28
2011/8/4 2:00	0.00	4100	26.6	4	28.1	105	1100	28
2011/8/4 4:00	-0.01	4100	26.7	4	28.1	105	1100	28
2011/8/4 6:00	0.00	4100	26.8	4	28.1	105	1100	28
2011/8/4 8:00	0.00	4100	26.7	4	28.1	105	1100	28
2011/8/4 10:00	0.00	4100	26.5	4	28.3	105	1100	28
2011/8/4 12:00	0.00	4100	26.3	4	28.3	105	1100	28
2011/8/4 14:00	0.00	4100	26.1	4	28.1	105	1100	28
2011/8/4 16:00	0.00	4100	26.0	4	28.1	105	1100	28
2011/8/4 18:00	0.00	4100	26.0	4	28.1	105	1100	28
2011/8/4 20:00	0.00	4100	26.0	4	28.1	105	1100	28
2011/8/4 22:00	0.00	4150	26.1	4	28.1	105	1100	28
2011/8/5 0:00	-0.01	4000	26.0	4	28.1	105	1100	28
2011/8/5 2:00	-0.01	4000	25.9	4	28.1	105	1100	28
2011/8/5 4:00	-0.01	4000	25.8	4	28.1	105	1100	28
2011/8/5 6:00	-0.01	4000	25.7	4	28.1	105	1100	28
2011/8/5 8:00	-0.01	4000	25.7	4	28.1	105	1100	28
2011/8/5 10:00	-0.01	4000	25.6	4	28.3	105	1100	28
2011/8/5 12:00	-0.01	4000	25.6	5	28.1	105	1100	28
2011/8/5 14:00								
2011/8/5 16:00								
2011/8/5 18:00								
2011/8/5 20:00								
2011/8/5 22:00								

2011年8月1日 11時14分 炉内監視システム

2F-3号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa (gage)]	炉水位 [mm] 停止時	炉水温度[°C]	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/8/3 0:00	0.02	4100	31.3	9	29.6	110	2100	28
2011/8/3 2:00	0.02	4100	31.0	9	29.6	110	2100	28
2011/8/3 4:00	0.02	4100	30.5	9	29.6	110	2100	28
2011/8/3 6:00	0.02	4150	30.1	9	29.6	110	2100	28
2011/8/3 8:00	0.02	4150	30.0	9	29.6	110	2100	28
2011/8/3 10:00	0.02	4150	30.1	9	29.6	110	2100	28
2011/8/3 12:00	0.02	4150	30.4	9	29.6	110	2100	28
2011/8/3 14:00	0.02	4150	30.5	9	29.6	110	2100	28
2011/8/3 16:00	0.02	4150	30.6	9	29.5	110	2100	28
2011/8/3 18:00	0.02	4150	30.6	9	29.6	110	2100	28
2011/8/3 20:00	0.02	4150	30.6	9	29.6	110	2100	28
2011/8/3 22:00	0.02	4150	30.5	9	29.6	110	2100	28
2011/8/4 0:00	0.02	4200	30.4	9	29.6	110	2100	28
2011/8/4 2:00	0.02	4000	30.3	9	29.5	110	2100	28
2011/8/4 4:00	0.02	4000	30.3	9	29.6	110	2100	28
2011/8/4 6:00	0.02	4000	30.4	9	29.5	110	2100	28
2011/8/4 8:00	0.02	4000	30.5	9	29.5	110	2100	28
2011/8/4 10:00	0.02	4000	30.4	9	29.5	110	2100	28
2011/8/4 12:00	0.02	4000	30.2	9	29.5	110	2100	28
2011/8/4 14:00	0.02	4000	30.0	9	29.5	110	2100	28
2011/8/4 16:00	0.02	4000	29.8	9	29.5	110	2100	28
2011/8/4 18:00	0.02	4000	29.7	9	29.5	110	2100	28
2011/8/4 20:00	0.02	4000	29.7	9	29.5	110	2100	28
2011/8/4 22:00	0.02	4000	29.8	9	29.5	110	2100	28
2011/8/5 0:00	0.02	4050	29.8	9	29.5	110	2100	28
2011/8/5 2:00	0.02	4050	29.7	9	29.5	110	2100	28
2011/8/5 4:00	0.02	4050	29.6	9	29.5	110	2100	28
2011/8/5 6:00	0.02	4050	29.5	9	29.5	110	2100	28
2011/8/5 8:00	0.02	4050	29.4	9	29.5	110	2100	28
2011/8/5 10:00	0.02	4100	29.3	9	29.5	111	2100	28
2011/8/5 12:00	0.02	4100	29.2	10	29.5	111	2100	28
2011/8/5 14:00								
2011/8/5 16:00								
2011/8/5 18:00								
2011/8/5 20:00								
2011/8/5 22:00								

2F-4号機

※燃料頂部(TAF)からの水位=炉水位+4200[mm]

時間	炉圧 [MPa (gage)]	炉水位 [mm] 停止時	炉水温度[°C]	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/8/3 0:00	0.07	4150	29.2	6	29.3	107	2050	28
2011/8/3 2:00	0.07	4000	29.1	6	29.3	107	2050	28
2011/8/3 4:00	0.07	4000	28.6	6	29.4	107	2050	28
2011/8/3 6:00	0.07	4000	28.2	6	29.3	107	2050	28
2011/8/3 8:00	0.07	4000	28.1	6	29.3	107	2050	28
2011/8/3 10:00	0.07	4000	28.1	6	29.2	107	2050	28
2011/8/3 12:00	0.07	4000	28.3	6	29.3	107	2050	28
2011/8/3 14:00	0.07	4000	28.5	6	29.4	107	2050	28
2011/8/3 16:00	0.07	4050	28.6	6	29.4	107	2050	28
2011/8/3 18:00	0.07	4050	28.6	6	29.3	107	2050	28
2011/8/3 20:00	0.07	4050	28.5	6	29.4	107	2050	28
2011/8/3 22:00	0.07	4050	28.5	6	29.4	107	2050	28
2011/8/4 0:00	0.07	4100	29.7	6	29.2	107	2050	28
2011/8/4 2:00	0.07	4150	29.6	6	29.4	107	2050	28
2011/8/4 4:00	0.08	4150	29.7	6	29.4	107	2050	28
2011/8/4 6:00	0.08	4050	29.7	6	29.4	107	2050	28
2011/8/4 8:00	0.07	4050	29.8	6	29.5	107	2050	28
2011/8/4 10:00	0.07	4050	29.8	6	29.5	107	2050	28
2011/8/4 12:00	0.07	4050	29.7	6	29.5	107	2050	28
2011/8/4 14:00	0.07	4050	29.6	6	29.5	107	2050	28
2011/8/4 16:00	0.07	4050	29.5	6	29.4	107	2050	28
2011/8/4 18:00	0.08	4100	29.3	6	29.4	107	2050	28
2011/8/4 20:00	0.08	4100	29.3	6	29.5	107	2050	28
2011/8/4 22:00	0.08	4100	29.3	6	29.4	107	2050	28
2011/8/5 0:00	0.07	4000	29.3	6	29.4	107	2050	28
2011/8/5 2:00	0.07	4000	29.2	6	29.4	107	2050	28
2011/8/5 4:00	0.07	4000	29.2	6	29.4	107	2050	28
2011/8/5 6:00	0.07	4000	29.1	6	29.4	107	2050	28
2011/8/5 8:00	0.07	4000	29.0	6	29.4	107	2050	28
2011/8/5 10:00	0.07	4000	28.9	6	29.5	107	2050	28
2011/8/5 12:00	0.07	4050	28.8	6	29.4	107	2050	28
2011/8/5 14:00								
2011/8/5 16:00								
2011/8/5 18:00								
2011/8/5 20:00								
2011/8/5 22:00								

2011年 8月 5日 17時 20分 炉内監視記録