













2F-1号機







2F-2号機



2F-3号機



2F-4号機







2F-4号機

※燃料頂部(TAF)からの水位 = 炉水位 + 4200[mm]





時間	炉圧 [MPa (gage)]	炉水位 [mm] 停止時	炉水温度[°C]	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/11/6 0:00	0.04	4150	28.9		29.5	101	2200	22
2011/11/6 2:00	0.04	4150	28.9		29.5	101	2200	22
2011/11/6 4:00	0.04	4150	28.9		29.5	101	2200	22
2011/11/6 6:00	0.03	4050	28.9		29.6	101	2200	22
2011/11/6 8:00	0.03	4050	28.9		29.6	101	2200	22
2011/11/6 10:00	0.03	4050	28.9		29.6	101	2200	22
2011/11/6 12:00	0.03	4050	28.8		29.6	101	2200	22
2011/11/6 14:00	0.03	4050	28.8		29.6	101	2200	22
2011/11/6 16:00	0.03	4050	28.8		29.6	101	2200	22
2011/11/6 18:00	0.03	4050	28.8		29.6	100	2200	22
2011/11/6 20:00	0.03	4050	28.8		29.6	100	2200	22
2011/11/6 22:00	0.03	4050	28.8		29.6	100	2200	22
2011/11/7 0:00	0.03	4050	28.8		29.5	100	2200	22
2011/11/7 2:00	0.03	4050	28.8		29.5	100	2200	22
2011/11/7 4:00	0.03	4050	28.7		29.5	100	2200	22
2011/11/7 6:00	0.03	4100	28.7		29.4	100	2200	22
2011/11/7 8:00	0.03	4100	28.7		29.5	100	2200	22
2011/11/7 10:00	0.03	4100	28.6		29.5	100	2200	22
2011/11/7 12:00	0.03	4100	28.6		29.5	100	2200	22
2011/11/7 14:00	0.04	4150	28.6		29.5	100	2200	22
2011/11/7 16:00	0.04	4150	28.6		29.5	100	2200	22
2011/11/7 18:00	0.04	4150	28.6		29.5	100	2200	22
2011/11/7 20:00	0.04	4150	28.5		29.5	100	2200	22
2011/11/7 22:00	0.04	4150	28.5		29.5	100	2200	22
2011/11/8 0:00	0.04	4200	28.5		29.6	100	2200	22
2011/11/8 2:00	0.04	4200	28.5		29.6	100	2200	22
2011/11/8 4:00	0.04	4200	28.4		29.4	100	2200	22
2011/11/8 6:00	0.03	4000	28.4		29.4	100	2200	22
2011/11/8 8:00								
2011/11/8 10:00								
2011/11/8 12:00								
2011/11/8 14:00								
2011/11/8 16:00								
2011/11/8 18:00								
2011/11/8 20:00								
2011/11/8 22:00								
2011/11/9 0:00								

D/W圧力について
 ・パーソナルエアロックドア開放中であるため、9/6 10:00 より記載せず





2F-1号機







2F-2号機



2F-3号機



2F-4号機



2F-4号機

※燃料頂部(TAF)からの水位 = 炉水位 + 4200[mm]

時間	炉圧 [MPa (gage)]	炉水位 [mm] 停止時	炉水温度[°C]	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/11/6 0:00	0.04	4150	28.9		29.5	101	2200	22
2011/11/6 2:00	0.04	4150	28.9		29.5	101	2200	22
2011/11/6 4:00	0.04	4150	28.9		29.5	101	2200	22
2011/11/6 6:00	0.03	4050	28.9		29.6	101	2200	22
2011/11/6 8:00	0.03	4050	28.9		29.6	101	2200	22
2011/11/6 10:00	0.03	4050	28.9		29.6	101	2200	22
2011/11/6 12:00	0.03	4050	28.8		29.6	101	2200	22
2011/11/6 14:00	0.03	4050	28.8		29.6	101	2200	22
2011/11/6 16:00	0.03	4050	28.8		29.6	101	2200	22
2011/11/6 18:00	0.03	4050	28.8		29.6	100	2200	22
2011/11/6 20:00	0.03	4050	28.8		29.6	100	2200	22
2011/11/6 22:00	0.03	4050	28.8		29.6	100	2200	22
2011/11/7 0:00	0.03	4050	28.8		29.5	100	2200	22
2011/11/7 2:00	0.03	4050	28.8		29.5	100	2200	22
2011/11/7 4:00	0.03	4050	28.7		29.5	100	2200	22
2011/11/7 6:00	0.03	4100	28.7		29.4	100	2200	22
2011/11/7 8:00	0.03	4100	28.7		29.5	100	2200	22
2011/11/7 10:00	0.03	4100	28.6		29.5	100	2200	22
2011/11/7 12:00	0.03	4100	28.6		29.5	100	2200	22
2011/11/7 14:00	0.04	4150	28.6		29.5	100	2200	22
2011/11/7 16:00	0.04	4150	28.6		29.5	100	2200	22
2011/11/7 18:00	0.04	4150	28.6		29.5	100	2200	22
2011/11/7 20:00	0.04	4150	28.5		29.5	100	2200	22
2011/11/7 22:00	0.04	4150	28.5		29.5	100	2200	22
2011/11/8 0:00	0.04	4200	28.5		29.6	100	2200	22
2011/11/8 2:00	0.04	4200	28.5		29.6	100	2200	22
2011/11/8 4:00	0.04	4200	28.4		29.4	100	2200	22
2011/11/8 6:00	0.03	4000	28.4		29.4	100	2200	22
2011/11/8 8:00	0.03	4000	28.3		29.4	100	2200	22
2011/11/8 10:00	0.03	4000	28.3		29.4	101	2200	22
2011/11/8 12:00	0.03	4000	28.2		29.3	100	2200	22
2011/11/8 14:00								
2011/11/8 16:00								
2011/11/8 18:00								
2011/11/8 20:00								
2011/11/8 22:00								
2011/11/9 0:00								

D/W圧力について

・パーソナルエアロックドア開放中であるため、9/6 10:00 より記載せず