













2F-1号機







2F-2号機







2F-3号機







2F-4号機







2F-1号機







2F-2号機



2F-3号機



2F-4号機



2F-1号機

※燃料頂部(TAF)からの水位 = 炉水位 + 4200[mm]

時間	炉圧 [MPa (gage)]	炉水位 [mm] 停止時	炉水温度[°C]	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/12/25 0:00	0.04	4150	26.1	0	21.3	100	2177	21
2011/12/25 2:00	0.04	4000	26.0	0	21.3	100	2177	21
2011/12/25 4:00	0.04	4000	26.0	0	21.3	100	2177	21
2011/12/25 6:00	0.03	4000	25.9	0	21.3	100	2177	21
2011/12/25 8:00	0.03	4000	25.9	0	21.2	100	2177	21
2011/12/25 10:00	0.03	4050	25.9	0	21.2	100	2177	21
2011/12/25 12:00	0.03	4050	25.9	0	21.2	100	2177	21
2011/12/25 14:00	0.03	4050	25.9	0	21.1	100	2177	21
2011/12/25 16:00	0.03	4050	25.9	0	21.1	100	2177	21
2011/12/25 18:00	0.03	4050	25.8	0	21.1	100	2177	21
2011/12/25 20:00	0.03	4050	25.8	0	21.1	100	2177	21
2011/12/25 22:00	0.03	4100	25.8	0	21.1	100	2176	21
2011/12/26 0:00	0.03	4100	25.8	0	21.1	100	2176	21
2011/12/26 2:00	0.03	4100	25.7	0	21.1	100	2176	21
2011/12/26 4:00	0.03	4100	25.6	0	21.1	100	2176	21
2011/12/26 6:00	0.03	4150	25.6	0	21.0	101	2176	21
2011/12/26 8:00	0.03	4150	25.6	0	21.1	101	2176	21
2011/12/26 10:00	0.04	4150	25.6	0	21.0	101	2176	21
2011/12/26 12:00	0.04	4150	25.5	0	20.9	101	2176	21
2011/12/26 14:00	0.04	4150	25.5	0	20.9	101	2176	21
2011/12/26 16:00	0.04	4200	25.5	0	20.9	101	2176	21
2011/12/26 18:00	0.03	4000	25.5	0	20.9	101	2175	21
2011/12/26 20:00	0.03	4000	25.5	0	20.9	101	2175	21
2011/12/26 22:00	0.03	4000	25.5	0	20.9	101	2175	21
2011/12/27 0:00	0.03	4000	25.5	0	20.9	101	2175	21
2011/12/27 2:00	0.03	4000	25.4	0	20.9	101	2175	21
2011/12/27 4:00	0.03	4000	25.4	0	20.9	101	2174	21
2011/12/27 6:00	0.03	4000	25.4	0	20.8	101	2174	21
2011/12/27 8:00	0.03	4050	25.3	0	20.8	101	2174	21
2011/12/27 10:00	0.03	4050	25.3	0	20.9	102	2174	21
2011/12/27 12:00	0.03	4050	25.4		21.1	102	2174	21
2011/12/27 14:00								
2011/12/27 16:00								
2011/12/27 18:00								
2011/12/27 20:00								
2011/12/27 22:00								
2011/12/28 0:00								

D/W圧力について

・パーソナルエアロックドア開放中であるため、12/27 10:06 より記載せず

