













2F-1号機







2F-2号機



2F-3号機



2F-4号機



2F-4号機





※燃料頂部(TAF)からの水位 = 炉水位 + 4200[mm]

時間	炉圧 [MPa (gage)]	炉水位 [mm] 停止時	炉水温度[°C]	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/11/29 0:00	0.02	4050	25.1		26.8	102	2200	20
2011/11/29 2:00	0.02	4050	25.1		26.8	102	2200	20
2011/11/29 4:00	0.02	4050	25.1		26.8	101	2200	20
2011/11/29 6:00	0.02	4050	25.1		26.8	101	2200	20
2011/11/29 8:00	0.02	4050	25.0		26.8	101	2200	20
2011/11/29 10:00	0.02	4100	25.0		26.8	102	2200	20
2011/11/29 12:00	0.02	4100	25.0		26.8	101	2200	20
2011/11/29 14:00	0.02	4100	25.0		26.8	101	2200	20
2011/11/29 16:00	0.02	4150	25.0		26.8	101	2200	20
2011/11/29 18:00	0.02	4150	25.0		26.8	101	2200	20
2011/11/29 20:00	0.02	4150	25.1		26.7	101	2200	20
2011/11/29 22:00	0.02	4150	25.1		26.7	101	2200	20
2011/11/30 0:00	0.02	4150	25.1		26.7	101	2200	20
2011/11/30 2:00	0.02	4150	25.1		26.7	101	2200	20
2011/11/30 4:00	0.02	4150	25.1		26.7	101	2200	20
2011/11/30 6:00	0.02	4000	25.1		26.7	101	2200	20
2011/11/30 8:00	0.01	4000	25.1		26.7	101	2200	20
2011/11/30 10:00	0.01	4000	26.7		26.6	101	2200	20
2011/11/30 12:00	0.01	4000	27.4		26.6	101	2200	20
2011/11/30 14:00	0.01	4000	27.4		26.7	101	2200	20
2011/11/30 16:00	0.01	4050	27.4		26.7	101	2200	20
2011/11/30 18:00	0.01	4050	27.4		26.8	101	2200	20
2011/11/30 20:00	0.01	4050	27.4		26.8	101	2200	20
2011/11/30 22:00	0.01	4050	27.4		26.9	101	2200	19
2011/12/1 0:00	0.01	4050	27.4		26.9	101	2200	19
2011/12/1 2:00	0.01	4050	27.4		26.9	101	2200	19
2011/12/1 4:00	0.01	4050	27.4		26.8	101	2200	19
2011/12/1 6:00	0.01	4050	27.3		26.9	101	2200	19
2011/12/1 8:00								
2011/12/1 10:00								
2011/12/1 12:00								
2011/12/1 14:00								
2011/12/1 16:00								
2011/12/1 18:00								
2011/12/1 20:00								
2011/12/1 22:00								
2011/12/2 0:00								





D/W圧力について

・パーソナルエアロックドア開放中であるため、9/6 10:00 より記載せず





2F-1号機







2F-2号機



2F-3号機



2F-4号機



2F-4号機

※燃料頂部(TAF)からの水位 = 炉水位 + 4200[mm]

時間	炉圧 [MPa (gage)]	炉水位 [mm] 停止時	炉水温度[°C]	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/11/29 0:00	0.02	4050	25.1		26.8	102	2200	20
2011/11/29 2:00	0.02	4050	25.1		26.8	102	2200	20
2011/11/29 4:00	0.02	4050	25.1		26.8	101	2200	20
2011/11/29 6:00	0.02	4050	25.1		26.8	101	2200	20
2011/11/29 8:00	0.02	4050	25.0		26.8	101	2200	20
2011/11/29 10:00	0.02	4100	25.0		26.8	102	2200	20
2011/11/29 12:00	0.02	4100	25.0		26.8	101	2200	20
2011/11/29 14:00	0.02	4100	25.0		26.8	101	2200	20
2011/11/29 16:00	0.02	4150	25.0		26.8	101	2200	20
2011/11/29 18:00	0.02	4150	25.0		26.8	101	2200	20
2011/11/29 20:00	0.02	4150	25.1		26.7	101	2200	20
2011/11/29 22:00	0.02	4150	25.1		26.7	101	2200	20
2011/11/30 0:00	0.02	4150	25.1		26.7	101	2200	20
2011/11/30 2:00	0.02	4150	25.1		26.7	101	2200	20
2011/11/30 4:00	0.02	4150	25.1		26.7	101	2200	20
2011/11/30 6:00	0.02	4000	25.1		26.7	101	2200	20
2011/11/30 8:00	0.01	4000	25.1		26.7	101	2200	20
2011/11/30 10:00	0.01	4000	26.7		26.6	101	2200	20
2011/11/30 12:00	0.01	4000	27.4		26.6	101	2200	20
2011/11/30 14:00	0.01	4000	27.4		26.7	101	2200	20
2011/11/30 16:00	0.01	4050	27.4		26.7	101	2200	20
2011/11/30 18:00	0.01	4050	27.4		26.8	101	2200	20
2011/11/30 20:00	0.01	4050	27.4		26.8	101	2200	20
2011/11/30 22:00	0.01	4050	27.4		26.9	101	2200	19
2011/12/1 0:00	0.01	4050	27.4		26.9	101	2200	19
2011/12/1 2:00	0.01	4050	27.4		26.9	101	2200	19
2011/12/1 4:00	0.01	4050	27.4		26.8	101	2200	19
2011/12/1 6:00	0.01	4050	27.3		26.9	101	2200	19
2011/12/1 8:00	0.01	4100	27.3		26.9	101	2200	19
2011/12/1 10:00	0.01	4100	27.2		26.9	101	2200	19
2011/12/1 12:00	0.01	4100	27.1		26.6	101	2200	19
2011/12/1 14:00								
2011/12/1 16:00								
2011/12/1 18:00								
2011/12/1 20:00								
2011/12/1 22:00								
2011/12/2 0:00								

D/W圧力について
・パーソナルエアロックドア開放中であるため、9/6 10:00 より記載せず