













2F-1号機







2F-2号機



2F-3号機



2F-4号機







2F-4号機

※燃料頂部(TAF)からの水位 = 炉水位 + 4200[mm]





時間	炉圧 [MPa (gage)]	炉水位 [mm] 停止時	炉水温度[°C]	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/11/21 0:00	0.02	4000	27.3		28.0	100	2200	21
2011/11/21 2:00	0.02	4000	27.3		28.0	100	2200	21
2011/11/21 4:00	0.02	4050	27.3		27.9	100	2200	21
2011/11/21 6:00	0.02	4050	27.3		28.0	100	2200	21
2011/11/21 8:00	0.02	4050	27.3		27.9	101	2200	21
2011/11/21 10:00	0.02	4050	27.3		27.9	101	2200	21
2011/11/21 12:00	0.02	4050	27.2		27.9	101	2200	21
2011/11/21 14:00	0.02	4050	27.2		27.9	101	2200	21
2011/11/21 16:00	0.02	4050	27.1		27.9	101	2200	21
2011/11/21 18:00	0.02	4050	27.1		27.9	101	2200	21
2011/11/21 20:00	0.02	4050	27.0		27.9	101	2200	21
2011/11/21 22:00	0.02	4050	26.9		27.9	101	2200	21
2011/11/22 0:00	0.02	4100	26.9		27.8	101	2200	20
2011/11/22 2:00	0.01	4100	26.8		27.8	101	2200	20
2011/11/22 4:00	0.01	4100	26.7		27.8	101	2200	20
2011/11/22 6:00	0.01	4100	26.6		27.8	101	2200	20
2011/11/22 8:00	0.01	4100	26.5		27.8	101	2200	20
2011/11/22 10:00	0.02	4100	26.4		27.8	101	2200	20
2011/11/22 12:00	0.02	4100	26.4		27.8	101	2200	20
2011/11/22 14:00	0.02	4150	26.4		27.8	101	2200	20
2011/11/22 16:00	0.02	4150	26.3		27.8	101	2200	20
2011/11/22 18:00	0.02	4150	26.3		27.8	102	2200	20
2011/11/22 20:00	0.02	4150	26.3		27.7	102	2200	20
2011/11/22 22:00	0.02	4150	26.3		27.7	101	2200	20
2011/11/23 0:00	0.02	4200	26.3		27.6	101	2200	20
2011/11/23 2:00	0.01	4000	26.2		27.7	101	2200	20
2011/11/23 4:00	0.01	4000	26.2		27.6	101	2200	20
2011/11/23 6:00	0.01	4000	26.1		27.6	101	2200	20
2011/11/23 8:00								
2011/11/23 10:00								
2011/11/23 12:00								
2011/11/23 14:00								
2011/11/23 16:00								
2011/11/23 18:00								
2011/11/23 20:00								
2011/11/23 22:00								
2011/11/24 0:00								

D/W圧力について
・パーソナルエアロックドア開放中であるため、9/6 10:00 より記載せず





2F-1号機







2F-2号機



2F-3号機



2F-4号機



2F-4号機

※燃料頂部(TAF)からの水位 = 炉水位 + 4200[mm]

時間	炉圧 [MPa (gage)]	炉水位 [mm] 停止時	炉水温度[°C]	D/W圧力 [kPa(gage)]	D/W温度 [°C]	S/C圧力 [kPa(abs)]	S/C水位 [mm]	S/C温度 [°C]
2011/11/21 0:00	0.02	4000	27.3		28.0	100	2200	21
2011/11/21 2:00	0.02	4000	27.3		28.0	100	2200	21
2011/11/21 4:00	0.02	4050	27.3		27.9	100	2200	21
2011/11/21 6:00	0.02	4050	27.3		28.0	100	2200	21
2011/11/21 8:00	0.02	4050	27.3		27.9	101	2200	21
2011/11/21 10:00	0.02	4050	27.3		27.9	101	2200	21
2011/11/21 12:00	0.02	4050	27.2		27.9	101	2200	21
2011/11/21 14:00	0.02	4050	27.2		27.9	101	2200	21
2011/11/21 16:00	0.02	4050	27.1		27.9	101	2200	21
2011/11/21 18:00	0.02	4050	27.1		27.9	101	2200	21
2011/11/21 20:00	0.02	4050	27.0		27.9	101	2200	21
2011/11/21 22:00	0.02	4050	26.9		27.9	101	2200	21
2011/11/22 0:00	0.02	4100	26.9		27.8	101	2200	20
2011/11/22 2:00	0.01	4100	26.8		27.8	101	2200	20
2011/11/22 4:00	0.01	4100	26.7		27.8	101	2200	20
2011/11/22 6:00	0.01	4100	26.6		27.8	101	2200	20
2011/11/22 8:00	0.01	4100	26.5		27.8	101	2200	20
2011/11/22 10:00	0.02	4100	26.4		27.8	101	2200	20
2011/11/22 12:00	0.02	4100	26.4		27.8	101	2200	20
2011/11/22 14:00	0.02	4150	26.4		27.8	101	2200	20
2011/11/22 16:00	0.02	4150	26.3		27.8	101	2200	20
2011/11/22 18:00	0.02	4150	26.3		27.8	102	2200	20
2011/11/22 20:00	0.02	4150	26.3		27.7	102	2200	20
2011/11/22 22:00	0.02	4150	26.3		27.7	101	2200	20
2011/11/23 0:00	0.02	4200	26.3		27.6	101	2200	20
2011/11/23 2:00	0.01	4000	26.2		27.7	101	2200	20
2011/11/23 4:00	0.01	4000	26.2		27.6	101	2200	20
2011/11/23 6:00	0.01	4000	26.1		27.6	101	2200	20
2011/11/23 8:00	0.01	4000	26.1		27.6	101	2200	20
2011/11/23 10:00	0.01	4000	26.0		27.6	101	2200	20
2011/11/23 12:00	0.01	4000	26.0		27.6	101	2200	20
2011/11/23 14:00								
2011/11/23 16:00								
2011/11/23 18:00								
2011/11/23 20:00								
2011/11/23 22:00								
2011/11/24 0:00								

D/W圧力について
 ・パーソナルエアロックドア開放中であるため、9/6 10:00 より記載せず