

NRA presentation

C Authorization Process C-2-3 REIA – Potential exposure

OTSUJI YAMAMOTO Ayako

Nuclear Regulation Authority JAPAN

IAEA Regulatory Review Mission on ALPS Treated Water Handling 23 March 2022



- 1. NRA's view on potential exposure assessment
- 2. Review on potential exposure assessment
 - 2-1. Potential exposure scenarios
 - 2-2. Source term
 - 2-3. Exposure pathways
 - 2-4. The representative person
 - 2-5. Comparison of estimated doses and risks with criteria



1. NRA's view on potential exposure assessment

external hazards.





FIG. 3. Components of an assessment for consideration of potential exposures. (The figure is not intended as a detailed step by step procedure and is presented to illustrate the elements of the assessment and facilitate its description.)



Approach to identification and selection of potential exposure scenarios

- No event progression is expected for the Discharge Facility, except continuation of unintended discharge.
- \Rightarrow Deterministic approach is sufficient.
- Not usual affiliated facility for nuclear reactor, but rather unique facility for this discharge
- ⇒ The likelihood does not have to be determined, and the impact of the identified event without the likelihood should be compared with the criteria 5mSv/event. The NRA has set this criteria referring to the value specified for a simple assessment with small inventories in GSG-10.



2. Review on potential exposure assessment



Major points to be clarified by TEPCO

 Concept of the assessment which does not follow the flow shown in Fig. 3 of GSG-10

Comments from the NRA for further clarification

- Consideration on possible internal exposure assuming the situations that unusual
 - occurrences continue without being detected or countermeasures are delayed



TEPCO explained the revised assessment at the NRA Review Meeting on 18 March 2022.



- Identified scenario is:
 - ✓ ALPS treated water discharge without mixing with seawater, directly to the ocean through pipe, assuming seawater intake pumps are stopped and emergency isolation valves are not closed.
 - ✓ The whole amount of one group of K4 tanks, approx. 10,000m³ ALPS treated water is discharged within 2 days.

Points to be further clarified

• The postulated scenario to derive the amount of discharge, approx.10,000m³, is unclear.



- The ratio of the nuclides other than tritium contained in ALPS treated water varies.
- ⇒ Calculation assuming each of 63 nuclides is contained up to concentration limit corresponding to the operational limit* (*the ratios of the radionuclides other than tritium to each concentration limit stipulated in the regulation is confirmed to be less than 1)
- ⇒ The largest impact among 63 nuclides is regarded as the assessment result, i.e., the assessment result of Te-127 which is the biggest contributer to external exposure.

Points to be further clarified

- The assumption that 63 nuclides are represented by Te-127 is extreme considering its half-life period.
- To be based on more realistic assumptions and then consider uncertainties



- In addition to one exposure pathway in the initial REIA (external exposure from the sea surface), adding the other exposure pathways to be on a conservative side:
 - ✓ External exposure during underwater work
 - ✓ Internal exposure during underwater work
 - ✓ External exposure from ship hull, beach sand and fishing net
 - ✓ Internal exposure due to intake of seafood

Points to be further clarified

 None	



- The representative person is identified as a shipman exposed to radiation through all the exposure pathways identified.
- The end point: 2days later considering emergency protective actions



Points to be further clarified

None



- Effective dose is calculated using the largest concentration value within 1km from the discharge point: 2.4E-10Bq/L
- External exposure is larger than internal exposure. Among 63 nuclides, Te-127 gives the biggest impact to external exposure.
- Assessment result with Te-127: 0.26mSv/event < the criteria 5mSv/event

Points to be further clarified

- The assumption that 63 nuclides are represented by Te-127 is extreme considering its half-life period.
- To be based on more realistic assumptions and then consider uncertainties