

# Event Notice Form

EXERCISE EXERCISE EXERCISE

## IAEA HEADER

IAEA ref. No.:  
Message Status: Not verified by IAEA  
Publication Note:  
Changes by IAEA:  
Fax Distribution List:  
Name of Duty Manager:

## Sender

Sender's Name: Keiichi Sasaki  
Competent Authority: Nuclear Regulation Authority (Japan)

## Event Details

Event Title: 【Drill】 Impact of the earthquake in the Iyo region of Ehime Prefecture on nuclear facilities  
Event Date: 2025-11-28  
Location / Facility: IKATA-3  
Event Country: Japan  
Event Type: Nuclear power plant

## Event Description

(Strong earthquake occurred at offshore Ehime Prefecture)  
Epicenter: 33.6N, 132.3E  
Depth: 10 km  
Magnitude: 7.5

### ●Ikata

Unit1: Under decommission  
Unit2: Under decommission  
Unit3: Under operation

The reactor of Ikata-3 was automatically shutdown due to the earthquake. Leakage of reactor coolant happened. ECCS doesn't operate due to some reason. Spent fuel pool was temporarily stopped and activated again. RHR was manually operated. Lost of external power, but two emergency diesel generators were operated.

### ●Shimane

Unit1: Under decommission  
Unit2: Under operation  
No abnormality was detected.

### ●Genkai

Unit1: Under decommission  
Unit2: Under decommission  
Unit3: Under operation  
Unit4: Under operation  
No abnormality was detected.

### ●Sendai

Unit1: Under operation  
Unit2: Under operation  
No abnormality was detected.

## Attachments and Links

Press Release Attached: No  
Technical Document Attached: No  
Further Information on Web:

## Contact Person for Further Information

Contact Person: Naoto ICHII  
Affiliation: Nuclear Regulation Authority  
Email: [REDACTED]  
Telephone: [REDACTED]  
Organization on Web:

EXERCISE