

EVENT NOTICE FORM

EXERCISE

>Sender

Sender's Name: **ONOHAMA Kai**
Competent Authority: **Nuclear Regulation Authority (Japan)**

>Event Details

Event Title: **Strong Earthquake Occurred in Hokkaido, Japan**
Event Date: **2026-11-06**
Location / Facility: **TOMARI-3**
Event Country: **Japan**
Event Type: **Power Reactor**

>Event Description

(Strong earthquake occurred at offshore Hokkaido prefecture)

Time: 05:00 (UTC)
Epicenter: 43.5N, 140.0E
Depth: 10 km
Magnitude: 8.0

Unit1: Maintenance outage
Unit2: Maintenance outage
Unit3: Under operation

Automatic reactor trip at 05:00 (UTC).
Stack monitor and monitoring posts: No abnormalities have been detected.
Spent fuel pool: A water leak occurred due to sloshing.
Loss of external power. Emergency diesel generators are supplying power, and cooling is being maintained.

>Attachments and Links

Press Release Attached: **No**
Technical Document Attached: **No**
Further Information on Web:

>Contact Person for Further Information

Contact Person: **Naoto ICHII**
Affiliation: **Nuclear Regulation Authority**
Email: **ichii_naoto_58i@nra.go.jp**
Telephone: **+81351142107**
Organization on Web: